



This configuration would apply only where the road is narrow with no shoulder. Future Phase circuits are shown in addition to Proposed Project circuits. Duct banks are shown for two cables/ph.



Source: Aspen, 2007

Sunrise Powerlink Project
 Figure Ap. 1-6
 Underground Cross-Section
 of Duct Bank