

*Southern California Edison*  
**MESA PTC A.15-03-003**

**DATA REQUEST SET A.15-03-003 ED-SCE-01**

**To:** ENERGY DIVISION  
**Prepared by:** Jason Carson  
**Title:** Project Manager  
**Dated:** 05/22/2015

---

**Question Q.07:**

**Removal of Existing Structures**

Pages 3-91 and 3-92 of the PEA mention the potential use of imported fill to backfill the holes left from removing temporary shoo-fly structures and wood poles. Provide the estimated volume that would be imported and potential source for this material.

**Response to Question Q.07:**

With the amount of spoil material expected to be generated from the installation of new above/below ground structures, the Project does not anticipate there being a need to import material for the backfill of existing or temporary transmission/subtransmission structures.