

Southern California Edison
MESA PTC A.15-03-003

DATA REQUEST SET A.15-03-003 ED-SCE-01

To: ENERGY DIVISION
Prepared by: Scott Lacy, P.E.
Title: Project Engineer
Dated: 05/22/2015

Question Q.31:

Cumulative Project--Distribution Circuit at Walnut Grove Avenue and Landis Lane

Provide additional details as to what the project entails and when construction of the project is anticipated to start and end.

Response to Question Q.31:

The work near Walnut Grove Avenue and Landis Lane, which is associated with adding a new 16 kV distribution circuit out of Rush Substation, consists of installing and splicing new cable and switching equipment in previously installed underground ducts and vaults. This effort is currently underway and is expected to be completed on or around August 31, 2015.