

Southern California Edison
MESA PTC A.15-03-003

DATA REQUEST SET A.15-03-003 ED-SCE-01

To: ENERGY DIVISION
Prepared by: Scott Lacy, P.E.
Title: Project Engineer
Dated: 05/22/2015

Question Q.24:

Hazardous Substances On Site

Provide a list of hazardous substances currently being stored or used at the Mesa Substation site, which would need to be handled, transported, or disposed of as part of the decommissioning of the existing substation.

Response to Question Q.24:

The hazardous substances currently stored or used at the Mesa Substation site consist of standard lubricants and paints, as well as mineral oil presently being used in existing transformers and circuit breakers. These materials would be collected and disposed of in accordance with all state and federal requirements for handling, transporting, and disposing of such materials, and in accordance with existing SCE procedures.