TABLE 4.5-32
PITTSBURG POWER PLANT CONCENTRATION ESTIMATES^a

Concentrations in Micrograms per Cubic Meter (µg/m³) Difference Power Plant Effect/Total Concentration^b Difference between 2005 2005 between 1999 Cumulative Cumulative 1999 Analytical Analytical **Analytical Delta Region** 1999 Analytical Maximum Maximum Averaging State National Period **Maximum**^d and Baseline and Baseline **Pollutant** Standard Standard **Background** Baseline Maximum 23,000 Carbon 1 hour 40,000 6,517 551.6/7,068 551.6/7,068 288.2/6,805 0 -263 Monoxide 8 hours 10,000 10,000 3.297 432.2/3,729 432.2/3,729 226/3,523 0 -206 470 0 -89 Nitrogen NA 132 350.8/483 350.8/483 262/394 1 hour^c Dioxide NA 100 31 20.0/51 46.1/77 9.3/40.3 26.1 annual -10.7Sulfur Dioxide 655 87 3.9/90.9 3.9/90.9 2.1/89.1 0 -1.8 1 hour NA 24 hours 105 365 24 1.6/25.6 1.6/25.6 0.8/24.8 0 -0.8 annual NA 80 3 0.14/3.10.3/3.30.13/3.10 -.01 Particulate 24 hours 50 150 60 12.3/72.3 15.9/75.9 7.4/67.4 3.6 -4.9 Matter 30 22 2.2/24.2 annual 50 1.1/23.1 1.0/231.1 -0.1(PM-10) Particulate 24 hours 65 ND 12.3/12.3 15.9/15.9 7.4/7.4 3.6 -4.9 NA 2.2/2.2 Matter annual NA 15 ND 1.1/1.11.0/1.01 -0.1(PM-2.5)

NA: Not applicable

ND: Not determined; PM-2.5 ambient monitoring has only recently begun in the Bay Area.

Values shown in bold type exceed a corresponding ambient air quality standard.

a The maximum receptor is approximately 0.3 miles east of the plant. Background concentrations (except for annual averages) represent the average of the 2nd highest values recorded each year from 1994 to 1996 at the Bethel Island monitoring station.

b In these columns, the number on the left shows the contributions of the power plants; the number on the right is the total contribution, including the Delta Region background.

Maximum NO2 concentrations from the power plant were calculated using the Ozone Limiting Method (Cole and Summerhays, 1979) based on a worst-case background ozone concentration of 133 micrograms per cubic meter.

d The 2005 Cumulative Analytical Maximum assumes new owners will have to comply with a modified BAAQMD Regulation 9, Rule 11 emission rate schedule similar to the existing schedule.