

TABLE B6-2
INDIVIDUAL PLANT CONTRIBUTIONS AT FUTURE CUMULATIVE CASE COMBINED
IMPACT POINT OF MAXIMUM CONCENTRATION

Pollutant/ Time Period	Combined Impact (µg/m3)	Pittsburg Contribution (µg/m3)	PDEF Contribution (µg/m3)	Contra Costa Contribution (µg/m3)
PM-10 / 24-hr	10.96	10.96	0.58	0.46
PM-10 / Annual	1.73	1.68	0.035	0.022
NO ₂ / 1-hr	271.4	271.4	6.25	12.78
NO ₂ / Annual	16.0	15.93	0.057	0.036

NOTE: The combined impact point of point of maximum is located on the PG&E Pittsburg Power Plant fenceline just east-northeast of Pittsburg Unit 1.