

ED14-SDGE 06/11/2015 Partial Response 1
A.14-04-011 SXPQ 230kV Transmission Line CPCN Project
Energy Division Data Request 14 Dated June 9, 2015
ED14-SDGE Questions 1-8

Q#	Summary of SDG&E Response Submittals	Confidential	PENDING Status
1-8	06/11/15 – Submittal 1: Q3	None.	Pending: Q1, Q2, Q4 - 8

Q#	Source Ref	Description/Data needed	SDGE Response
3	System Alternative	Provide a copy of SDG&E’s easement with MCAS Miramar for the Sycamore—Mission transmission corridor. Describe the operating and physical restrictions of the easement (i.e., pole heights, width of easement). Provide the easement and summary of restrictions by Thursday, June 11, 2015.	A copy of the requested easement has been included as Attachment ED14 – Q3. The easement is 200 feet wide and there are no restrictions enumerated in the easement document as to number, size, height or location of SDG&E facilities within the easement area. SDG&E would have to meet all applicable state and federal environmental requirements plus any FAA or flight operations requirements for structure heights. However, the easement does not include any specifics.

ED14-SDGE 06/11/2015 Partial Response 1
A.14-04-011 SXPQ 230kV Transmission Line CPCN Project
Energy Division Data Request 14 Dated June 9, 2015
ED14-SDGE Questions 1-8