



| SIZE | W FT. | L FT. | D INCH | C FT. | P INCH | * INCH |
|------|-------|-------|--------|-------|--------|--------|
| 18" | 3' | 5' | 12" | 1' | 4" | 6" |
| 24" | 4' | 6' | 12" | 1' | 4" | 6" |
| 30" | 5' | 7' | 18" | 1.5' | 4" | 6" |
| 36" | 6' | 9' | 18" | 1.5' | 8" | 12" |
| 42" | 7' | 11' | 24" | 2' | 8" | 12" |
| 48" | 8' | 13' | 24" | 2' | 12" | 18" |
| 54" | 9' | 15' | 30" | 2' | 12" | 18" |

REF: TRANSMISSION
CONSTRUCTION
STANDARDS SECTION 13

* LEAST DIMENSION OF ROCK TO BE USED