

Table B.3.12-2. Downs Substation Operational Noise Levels

Number	Location	Operational Daytime Noise Levels (dBA Leq)	Operational Nighttime Noise Levels (dBA Leq)	Peak Operational Noise Levels (dBA Leq)
1	Southeastern Property Line	57.3	53.6	60.9
2	Southern Property Line	61.2	57.2	64.6
3	Southwestern Property Line	55.7	51.6	59.1
4	Western Property Line	57.4	53.4	60.8
5	Northwestern Property Line	56.8	52.6	60.1
6	Northern Property Line	65.2	61.2	68.6
7	Northeastern Property Line	59.2	55.9	63.2
8	Eastern Property Line	60.8	57.7	64.9

Note: Number corresponds to location on Figure B.3.12-2.

Source: SCE, 2010a.