

Appendix (

Public Notice Materials



Notice of Intent to Adopt a Mitigated Negative Declaration And Notice of Public Meeting

for SDG&E's Vine Substation Project, Application No. A.14-05-021

The California Public Utilities Commission (CPUC) Energy Division has prepared a Mitigated Negative Declaration and supporting Initial Study (IS/MND) for consideration of SDG&E's application to construct the Vine Substation Project. SDG&E proposes to construct a new 69/12-kilovolt (kV) substation in the City of San Diego, near the San Diego International Airport, at the southwestern corner of the intersection of Vine Street and Kettner Boulevard, just west of Interstate 5. Approximately nine existing 12-kV distribution circuits would be relocated within existing and new underground conduit. The relocated distribution circuits would generally be placed within City of San Diego public streets in the Project area, including Columbia Street, India Street, Kettner Boulevard, Pacific Highway, Sassafras Street, State Street, Vine Street, West Laurel Street, West Hawthorn Street, West Palm Street, and West Redwood Street. An existing 69-kV power line would be looped in to the proposed Vine Substation, which involves removing two existing wood poles near the corner of California Street and Vine Street and installing three new self-supported tubular steel poles adjacent to Pacific Highway. To connect the proposed Vine Substation and the existing Kettner Substation to SDG&E's telecommunication system, fiber optic cable would be installed, generally within the underground 12-kV distribution duct banks and would require a 100-foot overhead connection into the Vine Substation. The Project is proposed to meet existing and anticipated customer-driven electrical load growth, and to improve distribution equipment reliability to prevent potential long outages or disruption of service to existing SDG&E customers in downtown and the surrounding area. Construction is anticipated to begin in January 2016 and would last through July 2017 (19 months), depending on CPUC approval. Based on this document, it has been determined that the Proposed Project, as mitigated, would not have any significant effects on the environment. The IS/MND is available on the CPUC's website or at various repositories in the Project area, including the Mission Hills Branch Library (925 Washington Street, San Diego). Additional repository locations are listed on the CPUC's website.

For electronic access to the IS/MND and other project information/reports, please check the CPUC's website at:

<http://www.cpuc.ca.gov/environment/info/asp/vine/vine.htm>

The CPUC will hold a public meeting on **Wednesday October 7, 2015 from 6:00 p.m. to 8:00 p.m. at the Sheraton San Diego Hotel & Marina, located at 1380 Harbor Island Drive. Parking validation will be provided.** The public meeting is an opportunity to learn about the Proposed Project, ask questions about the content of the Draft IS/MND, and provide comments. Written comments will be accepted during the meeting; there will be no facilities to record oral comments.

The comment period for the Draft IS/MND is from September 21 through October 20, 2015. Comments may be submitted by email or U.S. Mail. Please be sure to include your name, address, and telephone number. Written comments on the Draft IS/MND should be sent to: CPUC Vine Substation Project; c/o Aspen Environmental Group; 5020 Chesebro Road, Suite 200; Agoura Hills, CA 91301; Email: Vine-Substation-Project@aspeneq.com. To request additional information, call the Project Voicemail at (888) 463-0002.

California Newspaper Service Bureau

Public Notice Advertising Since 1934

Tel 1-800-788-7840 Fax 1-800-474-9444

Local Offices and Representatives in:

Los Angeles, Santa Ana, San Diego, Riverside/San Bernardino,

San Francisco, Oakland, San Jose, Sacramento

Special Services Available in Phoenix

Legal Notices

Notice of Intent to Adopt a Mitigated Negative Declaration And Notice of Public Meeting for SDG&E's Vine Substation Project, Application No. A 14-05-021

The California Public Utilities Commission (CPUC) Energy Division has prepared a Mitigated Negative Declaration and supporting Initial Study (IS/MND) for consideration of SDG&E's application to construct the Vine Substation Project. SDG&E proposes to construct a new 69/12-kilovolt (kV) substation in the City of San Diego, near the San Diego International Airport, at the southwestern corner of the intersection of Vine Street and Kettner Boulevard, just west of Interstate 5. Approximately nine existing 12-kV distribution circuits would be relocated within existing and new underground conduit. The relocated distribution circuits would generally be placed within City of San Diego public streets in the Project area, including Columbia Street, India Street, Kettner Boulevard, Pacific Highway, Sasafas Street, State Street, Vine Street, West Laurel Street, West Hawthorn Street, West Palm Street, and West Reswood Street. An existing 69-kV power line would be looped into the proposed Vine Substation, which involves removing two existing wood poles near the corner of California Street and Vine Street and installing three new self-supported tubular steel poles adjacent to Pacific Highway. To connect the proposed Vine Substation and the existing Kettner Substation to SDG&E's telecommunication system, fiber optic cable would be installed, generally within the underground 12-kV distribution duct bank and would require a 100-foot overhead connection into the Vine Substation. The Project is proposed to meet existing and anticipated customer-driven electrical load growth, and to improve distribution equipment reliability to prevent potential long outages or disruption of service to existing SDG&E customers in downtown and the surrounding area. Construction is anticipated to begin in January 2016 and would last through July 2017 (19 months), depending on CPUC approval. Based on this document, it has been determined that the Proposed Project, as mitigated, would not have any significant effects on the environment. The IS/MND is available on the CPUC's website or at various repositories in the Project area, including the Mission Hills Branch Library (925 Washington Street, San Diego). Additional repository locations are listed on the CPUC's website. For electronic access to the IS/MND and other project information/reports, please check the CPUC's website at: <http://www.cpuc.ca.gov/environment/info/asper/vine/vine.htm> The CPUC will hold a public meeting on Wednesday, October 7, 2015, from 6:00 p.m. to 8:00 p.m., at the Sheraton San Diego Hotel & Marina, located at 1380 Harbor Island Drive, Parking validation will be provided. The public meeting is an opportunity to learn about the Proposed Project, ask questions about the content of the Draft IS/MND, and provide comments. Written comments will be accepted during the meeting; there will be no facilities to record oral comments. The comment period for the Draft IS/MND is from September 21 through October 20, 2015. Comments may be submitted by email or U.S. Mail. Please be sure to include your name, address, and telephone number. Written comments on the Draft IS/MND should be sent to: CPUC Vine Substation Project, c/o Aspen Environmental Group, 5020 Chesebro Road, Suite 200, Agoura Hills, CA 91301. Email: Vine-Substation-Project@aspeng.com. To request additional information, call the Project VoiceMail at (888) 463-0002. 9/21/15 CMS: 21949008 THE SAN DIEGO UNION

DECLARATION

I am a resident of Los Angeles County, over the age of eighteen years and not a party to or interested in the matter noticed.

The notice, of which the annexed is a printed copy appeared in the:

SAN DIEGO UNION

On the following dates:

09/21/2015

I certify (or declare) under penalty of perjury that the foregoing is true and correct.

Dated at Los Angeles, California, this

26th day of October 2015



Signature

2794900

"The only Public Notice which is justifiable from the standpoint of true economy and the public interest, is that which reaches those who are affected by it"



* A 0 0 0 0 0 3 8 9 5 3 4 6 *

California Newspaper Service Bureau®

Public Notice Advertising Since 1934
Tel 1-800-788-7840 • Fax 1-800-540-1089
Local Offices and Representatives in:
Los Angeles, Santa Ana, San Diego, Riverside/San Bernardino,
San Francisco, Oakland, San Jose, Sacramento
Special Services Available in Phoenix.

DECLARATION

I am a resident of San Diego County, over the age of eighteen years and not a party to any or interested in the matter noticed.

The notice, of which the annexed is a printed copy appeared in the:

THE SAN DIEGO UNION TRIBUNE

A newspaper of general circulation adjudicated for the City Oceanside and the City of Escondido, County of San Diego under the County Superior Court, Decree No. 171349, for the County of San Diego

On the following dates:

December 04, 2015

I certify (or declare) under penalty of perjury that the foregoing is true and correct.

Dated at San Diego, California, this

18th day of December 2015

[Handwritten signature of Yolanda Cordova]

YOLANDA CORDOVA

CNS#2821889

"The only Public Notice which is justifiable from the standpoint of true economy and the public interest, is that which reaches those who are affected by it"

Rev 1/2014 Daily Journal Corporation, 915 East First Street, Los Angeles, CA 90012



NOTICE OF INTENT TO ADOPT A MITIGATED NEGATIVE DECLARATION for SDG&E's Vine Substation Project, Application No. A.14-05-021

Project Background: A Draft Mitigated Negative Declaration (MND) was released on September 21, 2015. Following the close of the review period (October 20, 2015), SDG&E informed the CPUC of a potential conflict with a planned sewer pipeline project, which includes replacement, rehabilitation, and realignment of sewer mains within Columbia Street, from West Quince Street to Laurel Street, and within portions of Quince, Palm, Olive, Union, and State Streets. Due to the presence of existing underground utilities, the potential exists that a portion of Columbia Street would be too constrained to allow for installation of both the sewer line and the proposed distribution line. As such, SDG&E has proposed an approximately 1,000-foot realignment option which would instead route the 12-kV duct banks along India Street between West Redwood Street and West Palm Street, and then along West Palm Street to Columbia Street to avoid the segment of Columbia Street between West Redwood Street and West Palm Street. The MND and supporting Initial Study (IS/MND) has been revised to address this alignment option, as well as comments received on the original Draft IS/MND. Proposed Project: SDG&E proposes to construct a new 69/12-kilovolt (kV) substation in the City of San Diego, near the San Diego International Airport, at the southwestern corner of the intersection of Vine Street and Kettner Boulevard, just west of Interstate 5. Approximately nine existing 12-kV distribution circuits would be relocated within existing and new underground conduit. The relocated distribution circuits would generally be placed within the franchise portion of City of San Diego public streets (public rights-of-way) in the Project area, including Columbia Street, India Street, Kettner Boulevard, Pacific Highway, Sassafras Street, State Street, Vine Street,

West Laurel Street, West Hawthorn Street, West Palm Street, and West Redwood Street. The proposed alignment option for the 12-kV distribution line would utilize India Street between West Redwood Street and West Palm Street, and then West Palm Street to Columbia Street. An existing 69-kV power line would be looped in to the proposed Vine Substation. To connect the proposed Vine Substation and existing Kettner Substation to SDG&E's telecommunication system, fiber optic cable would be installed, generally within the underground 12-kV distribution duct banks and would require a 100-foot overhead connection into the Vine Substation. The Project is proposed to meet existing and anticipated customer-driven electrical load growth, and to improve distribution equipment reliability to prevent potential long outages or disruption of service to existing SDG&E customers in downtown and the surrounding area. Construction is anticipated March 2016-July 2017 (17 months), depending on CPUC approval. Based on the Revised IS/MND, it has been determined that the Project, as mitigated, would not have any significant effects on the environment. The IS/MND is available on the CPUC's website or at various repositories in the Project area, including the Mission Hills Branch Library. Additional repository locations are listed on the CPUC's website: http://www.cpuc.ca.gov/environment/info/asp/vine/vine.htm The comment period for the Revised Draft IS/MND is from December 4, 2015 through January 4, 2016. Comments may be submitted by email or U.S. Mail. Please be sure to include your name, address, and telephone number. Written comments on the Draft IS/MND should be sent to: CPUC Vine Substation Project; c/o Aspen Environmental Group; 5020 Chesebro Road, Suite 200; Agoura Hills, CA 91301; Email: Vine-Substation-Project@aspenerg.com. To request additional information, call the Project VoiceMail at (888) 463-0002. 12/4/15 CNS-2821889# THE SAN DIEGO UNION

THE DAILY TRANSCRIPT

This space for filing stamp only

2652 4TH AVE 2ND FL, SAN DIEGO, CA 92103
Telephone (619) 232-3486 / Fax (619) 270-2503

Patrick Meddaugh
ASPEN ENVIRONMENTAL GROUP
5020 CHESEBRO RD #200
AGOURA HILLS, CA - 91301

SD #: 2794918

Notice of Intent to Adopt a Mitigated Negative Declaration And Notice of Public Meeting for SDG&E's Vine Substation Project, Application No. A.14-05-021

The California Public Utilities Commission (CPUC) Energy Division has prepared a Mitigated Negative Declaration and supporting Initial Study (IS/MND) for consideration of SDG&E's application to construct the Vine Substation Project. SDG&E proposes to construct a new 69/12-kilovolt (kV) substation in the City of San Diego, near the San Diego International Airport, at the southwestern corner of the intersection of Vine Street and Kettner Boulevard, just west of Interstate 5. Approximately nine existing 12-kV distribution circuits would be relocated within existing and new underground conduit. The relocated distribution circuits would generally be placed within City of San Diego public streets in the Project area, including Columbia Street, India Street, Kettner Boulevard, Pacific Highway, Sassafras Street, State Street, Vine Street, West Laurel Street, West Hawthorn Street, West Palm Street, and West Redwood Street. An existing 69-kV power line would be looped in to the proposed Vine Substation, which involves removing two existing wood poles near the corner of California Street and Vine Street and installing three new self-supported tubular steel poles adjacent to Pacific Highway. To connect the proposed Vine Substation and the existing Kettner Substation to SDG&E's telecommunication system, fiber optic cable would be installed, generally within the underground 12-kV distribution duct banks and would require a 100-foot overhead connection into the Vine Substation. The Project is proposed to meet existing and anticipated customer-driven electrical load growth, and to improve distribution equipment reliability to prevent potential long outages or disruption of service to existing SDG&E customers in downtown and the surrounding area. Construction is anticipated to begin in January 2016 and would last through July 2017 (19 months), depending on CPUC approval. Based on this document, it has been determined that the Proposed Project, as mitigated, would not have any significant effects on the environment. The IS/MND is available on the CPUC's website or at various repositories in the Project area, including the Mission Hills Branch Library (925 Washington Street, San Diego). Additional repository locations are listed on the CPUC's website. For electronic access to the IS/MND and other project information/reports, please check the CPUC's website at: http://www.cpuc.ca.gov/environment/infolaspenvine/vine.htm The CPUC will hold a public meeting on Wednesday October 7, 2015 from 6:00 p.m. to 8:00 p.m. at the Sheraton San Diego Hotel & Marina, located at 1380 Harbor Island Drive. Parking validation will be provided. The public meeting is an opportunity to learn about the Proposed Project, ask questions about the content of the Draft IS/MND, and provide comments. Written comments will be accepted during the meeting; there will be no facilities to record oral comments.

The comment period for the Draft IS/MND is from September 21 through October 20, 2015 - Comments may be submitted by email or U.S. Mail. Please be sure to include your name, address, and telephone number. Written comments on the Draft IS/MND should be sent to: CPUC Vine Substation Project; c/o Aspen Environmental Group; 5020 Chesebro Road, Suite 200; Agoura Hills, CA 91301; Email: Vine-Substation-Project@aspeneeg.com. To request additional information, call the Project Voicemail at (888) 463-0002. 9/21/15

SD-2794918#

PROOF OF PUBLICATION

(2015.5 C.C.P.)

State of California)
County of SAN DIEGO) ss

Notice Type: GPN - GOVT PUBLIC NOTICE

Ad Description:

SDG&E's Vine Substation Project, Application No. A.14-05-021

I am a citizen of the United States and a resident of the State of California; I am over the age of eighteen years, and not a party to or interested in the above entitled matter. I am the principal clerk of the printer and publisher of THE DAILY TRANSCRIPT, a newspaper published in the English language in the city of SAN DIEGO, and adjudged a newspaper of general circulation as defined by the laws of the State of California by the Superior Court of the County of SAN DIEGO, State of California, under date of 05/13/2003, Case No. GIC808715. That the notice, of which the annexed is a printed copy, has been published in each regular and entire issue of said newspaper and not in any supplement thereof on the following dates, to-wit:

09/21/2015

Executed on: 09/21/2015
At Los Angeles, California

I certify (or declare) under penalty of perjury that the foregoing is true and correct.

[Handwritten Signature]

Signature



THE DAILY TRANSCRIPT

2652 4TH AVE 2ND FL, SAN DIEGO, CA 92103
Telephone (619) 232-3486 / Fax (619) 270-2503

LISA BEWITT
ASPEN ENVIRONMENTAL GROUP
5020 CHESEBRO RD #200
AGOURA HILLS, CA - 91301

PROOF OF PUBLICATION

(2015.5 C.C.P.)

State of California)
County of SAN DIEGO) ss

Notice Type: GPN - GOVT PUBLIC NOTICE

Ad Description:

SDG&E's Vine Substation Project, Application No. A.14-05-021

I am a citizen of the United States and a resident of the State of California; I am over the age of eighteen years, and not a party to or interested in the above entitled matter. I am the principal clerk of the printer and publisher of THE DAILY TRANSCRIPT, a newspaper published in the English language in the city of SAN DIEGO, and adjudged a newspaper of general circulation as defined by the laws of the State of California by the Superior Court of the County of SAN DIEGO, State of California, under date of 05/13/2003, Case No. GIC808715. That the notice, of which the annexed is a printed copy, has been published in each regular and entire issue of said newspaper and not in any supplement thereof on the following dates, to-wit:

12/04/2015

Executed on: 12/04/2015
At Los Angeles, California

I certify (or declare) under penalty of perjury that the foregoing is true and correct.

[Handwritten Signature]

Signature



This space for filing stamp only

SD #: 2821890

NOTICE OF INTENT TO ADOPT A MITIGATED NEGATIVE DECLARATION for SDG&E's Vine Substation Project, Application No. A.14-05-021

Project Background: A Draft Mitigated Negative Declaration (MND) was released on September 21, 2015. Following the close of the review period (October 20, 2015), SDG&E informed the CPUC of a potential conflict with a planned sewer pipeline project, which includes replacement, rehabilitation, and realignment of sewer mains within Columbia Street, from West Quince Street to Laurel Street, and within portions of Quince, Palm, Olive, Union, and State Streets. Due to the presence of existing underground utilities, the potential exists that a portion of Columbia Street would be too constrained to allow for installation of both the sewer line and the proposed distribution line. As such, SDG&E has proposed an approximately 1,030-foot realignment option which would instead route the 12-kV duct banks along India Street between West Redwood Street and West Palm Street, and then along West Palm Street to Columbia Street to avoid the segment of Columbia Street between West Redwood Street and West Palm Street. The MND and supporting Initial Study (IS/MND) has been revised to address this alignment option, as well as comments received on the original Draft IS/MND.

Proposed Project: SDG&E proposes to construct a new 69/12-kilovolt (kV) substation in the City of San Diego, near the San Diego International Airport, at the southwestern corner of the intersection of Vine Street and Kettner Boulevard, just west of Interstate 5. Approximately nine existing 12-kV distribution circuits would be relocated within existing and new underground conduit. The relocated distribution circuits would generally be placed within the franchise portion of City of San Diego public streets (public rights-of-way) in the Project area, including Columbia Street, India Street, Kettner Boulevard, Pacific Highway, Sassafras Street, State Street, Vine Street, West Laurel Street, West Hawthorn Street, West Palm Street, and West Redwood Street. The proposed alignment option for the 12-kV distribution line would utilize India Street between West Redwood Street and West Palm Street, and then West Palm Street to Columbia Street. An existing 69-kV power line would be looped in to the proposed Vine Substation. To connect the proposed Vine Substation and existing Kettner Substation to SDG&E's telecommunication system, fiber optic cable would be installed generally within the underground 12-kV distribution duct banks and would require a 100-foot overhead connection into the Vine Substation. The Project is proposed to meet existing and anticipated customer-driven electrical load growth, and to improve distribution equipment reliability to prevent potential long outages or disruption of service to existing SDG&E customers in downtown and the surrounding area. Construction is

anticipated March 2016-July 2017 (17 months), depending on CPUC approval. Based on the Revised IS/MND, it has been determined that the Project, as mitigated, would not have any significant effects on the environment. The IS/MND is available on the CPUC's website or at various repositories in the Project area, including the Mission Hills Branch Library. Additional repository locations are listed on the CPUC's website: http://www.cpuc.ca.gov/environment/info/aspn/vine/vine.htm The comment period for the Revised Draft IS/MND is from December 4, 2015 through January 4, 2016. Comments may be submitted by email or U.S. Mail. Please be sure to include your name, address, and telephone number. Written comments on the Draft IS/MND should be sent to: CPUC Vine Substation Project, c/o Aspen Environmental Group, 5020 Chesebro Road, Suite 200, Agoura Hills, CA 91301; Email: Vine-Substation-Project@aspenev.com. To request additional information, call the Project Voicemail at (888) 463-0002. 12/4/15

SD-2821890#