

Southern California Edison
WODUP A.13-10-020

DATA REQUEST SET A.13-10-020 WODUP ED-SCE-02

To: ENERGY DIVISION
Prepared by: James Ruther
Title: MPP1
Dated: 04/02/2014

Question BIO-08e:

Biological Resources

BIO-8 Impact areas.

e. In Table 3.2-F, the total disturbance area of guy structures is shown as 1.4 acres, but temporary and permanent impact acreages are both listed as 0. Please provide values for temporary and permanent impacts for guy structures.

Response to Question BIO-08e:

Guy structures typically have a diameter of 1 to 1.5 feet plus a 5-foot clearance (for O&M purposes). This disturbance would be a permanent impact, most of which would likely occur within the street right of way. Based on these dimensions, the disturbance area for one guy structure would equate to approximately 103.87 square feet (permanent impact) which equals 0.00238452 of an acre. The values in the table were due to rounding and would remain 0 for both the temporary and permanent impacts.