

Southern California Edison
WODUP A.13-10-020

DATA REQUEST SET A.13-10-020 WODUP ED-SCE-04

To: ENERGY DIVISION
Prepared by: Scott Lacy, P.E.
Title: Project Engineer
Dated: 04/24/2014

Question PD-15:

In reviewing the GIS data (dated January 31, 2014), the structure heights appear to be missing for three existing towers outside of El Casco Substation. Please provide the structure height for each tower (T72A, T72B and T72C) listed in the table below.

Segment	Circuit	Type	Tower ID
3	Devers-El Casco	LST	T72A
3	El Casco-San Bernardino	LST	T72B
4	Devers-El Casco	LST	T72C

Response to Question PD-15:

The metadata has been updated for these 3 structures outside El Casco Substation and will be included in a subsequent submittal of GIS data.

In advance of that submittal, here are their heights:

T72A - 128'

T72B - 131'

T72C - 131'