

**Southern California Edison
MESA PTC A.15-03-003**

DATA REQUEST SET A1503003 ED-SCE-02

**To: ENERGY DIVISION
Prepared by: Daniel Donaldson
Title: Power System Planner
Dated: 07/22/2015**

Received Date: 07/17/2015

Question 03:

Describe the function served by connecting the Goodrich–Laguna Bell and Laguna Bell–Rio Hondo 220-kV transmission lines to the Mesa Substation.

Response to Question 03:

The function of connecting the Goodrich – Laguna Bell and Laguna Bell – Rio Hondo 220-kV transmission lines to Mesa substation is to provide new transmission source lines and to distribute power toward coastal cities South of Mesa Substation.