

Southern California Edison
A.23-03-005 – Cal City PTC

DATA REQUEST SET E D - S C E - 0 0 2

To: Energy Division
Prepared by: Sheridan Mascarenhas
Job Title: Senior Advisor
Received Date: 7/25/2023

Response Date: 8/4/2023

Question 04:

Purpose and Objectives: Is the South Base Substation load included in the Electric Needs Area (ENA) demand? What is that load/demand?

Response to Question 04:

The ENA does not include the South Base Substation located on Edwards Air Force Base. South Base Substation is a dedicated customer substation that exclusively serves military customer demand. The year-to-date peak demand at South Base Substation was 20.6 MW, recorded on July 20, 2023.