

SDG&E TL 6975 SAN MARCOS TO ESCONDIDO PROJECT (A.17-11-010)

ENERGY DIVISION DATA REQUEST #9 – JULY 8, 2019

SDG&E RESPONSE #9 – JULY 9, 2019

Request: Provide confirmation of the offset distance of 50 feet between the proposed TL6975 alignment and the existing TL13811/13825 alignment in Segment 2.

Response: SDG&E hereby confirms the offset distance of 50 feet between the proposed TL6975 alignment and the existing TL13811/13825 alignment in Segment 2 of the Proposed Project. SDG&E notes that the 50 feet is based on a centerline to centerline measurement.