

Southern California Edison
Circle City and Mira Loma-Jefferson PTC A.15-12-007

DATA REQUEST SET A1512007 ED-SCE-18

To: ENERGY DIVISION
Prepared by: Kashif Siddiqi
Title: Project Engineer
Dated: 08/10/2018

Question 18.07:

Clarify whether SCE would install a tan colored wall around the battery storage facility site associated with Alternative D1 similar to that SCE has proposed for Circle City Substation site.

Response to Question 18.07:

SCE would install a tall tan-colored wall with a minimum height of 8 feet around the battery storage facility site associated with Alternative D1, similar to that which SCE has proposed for the Circle City Substation site.