TABLE 4.4.3: EDISON INLAND FACILITY NPDES PERMITS AND COOLING WATER DISCHARGES

									Maximum Chlorine Levels (mg/L)	
Power Plant	Permit Number	Order Number	Expiration Date	Outfall Number	Receiving Water	Allowable Maximum Flow (mgd)	Allowable Maximum Temperatures (°F)	pH Maximum	Total Residual	Free
Cool Water	N/A	6-84-20	N/A	N/A	N/A	0.82	N/A	N/A	N/A	N/A
Note: Power plant discharges to five on-site clay-lined evaporation ponds.										
Etiwanda	POTW #10358	N/A	N/A	N/A	Sanitary Sewer LA County Sanitation District	3.36	120	6-12.5	N/A	N/A

Note: The discharge is to the sanitary sewer and the permit is issued by the Chino Basin Municipal Water District. The permit allows for the discharge of cooling tower water and other facility sources; however, surface runoff is not allowed in the discharge and the discharge may not contain volatile

hydrocarbons. Rainwater (surface water) collected within the storage tank impound areas is allowed to evaporate.

Highgrove	CA001555	94-95	9/1/99			0.611				
				001	Evaporation pond	N/A	95	6.5-8.5	0.1	N/A
					with overflow into					
					Santa Ana River					
				002	Lake Cadena	N/A	95	6.5-8.5	0.1	N/A
					which overflows					
					into the Santa					
					Ana River					
				003	Riverside Canal	N/A	N/A	6.5-8.5	N/A	N/A
Note: Power plant is used only in summer and has intermittent discharges.										
San	CA0001210	94-8	3/1/99				2.1	95		
Bernardino										
				001	Santa Ana River	1.075	95	6.5-9	0.1	20
				002	Riverside Canal	1.075	N/A	6.5-9	0.5	65

Note: Power plant is used only in summer and has intermittent discharges.

NOTES: mgd = millio

 $mgd = million \ gallons \ per \ day. \hspace{1cm} N/A = not \ applicable/available.$

 $s{:}=summer\ temperatures. \hspace{1cm} w=winter\ temperatures.$

 $mg/L = milligrams \ per \ liter. \\ \hspace{1.5cm} ^{\circ}F = degrees \ Fahrenheit.$

^{*} requirements if Section 301g variance is not passed/requirements if passed.