

**TABLE 4.5-35
COMPARISON WITH '97 CLEAN AIR PLAN POWER PLANT EMISSIONS ESTIMATES, 2000**

Pollutant	Emissions (tons per year)		
	Year 2000		
	Baseline	A-Max	'97 CAP ^a
With Continued Application of BAAQMD Regulation 9, Rule 11:			
Reactive Organic Gases	431	785	177
Nitrogen Oxides	3,796	7,552	4,928
Particulate Matter	388	708	376
Without Continued Application of BAAQMD Regulation 9, Rule 11^b:			
Nitrogen Oxides	3,796	9,590	NA ^c

^a Emissions estimates included in the '97 *Clean Air Plan* were adjusted from tons per day to tons per year. In addition, the '97 *Clean Air Plan* estimates for ROG and PM-10 from power plants were adjusted to reflect the latest EPA emissions factors for natural gas combustion, which were used to develop the power plant emissions estimates contained in this report.

^b For this case, only emissions of nitrogen oxides are shown. The other criteria pollutants shown above would be essentially the same with or without Regulation 9, Rule 11. Therefore, these emissions were not repeated for this case.

^c NA = not applicable; the 1997 Clean Air Plan assumes that BAAQMD Regulation 9, Rule 11 would apply to the Bay Area power plants.