

TABLE B6-1
SUMMARY OF FUTURE CUMULATIVE AIR QUALITY AT MAXIMUM RECEPTOR POINTS
FOR PG&E PLANTS AND PROPOSED ENRON POWER PLANT IN 2005

Pollutant/ Time Period	Combined Impact (µg/m3)	Pittsburg Only (µg/m3)	PDEF Only (µg/m3)	Contra Costa Only (µg/m3)
PM-10 / 24-hr	10.96	10.96	2.18	7.87
PM-10 / Annual	1.73	1.68	0.38	1.28
NO ₂ / 1-hr	271.4	271.4	16.3	61.1
NO ₂ / Annual	16.0	15.9	0.64	2.06

NOTE: The concentrations shown on this table are shown for the respective points of maximum impact. For each value shown, these points are not necessarily located at the same location. Locations of these points are discussed in the text of this response.