Southern California Edison Presidential Substation Project A.08-12-023

DATA REQUEST SET Presidential ED-03 (Part 1)

To: CPUC Prepared by: Jack Haggenmniller Title: Field Engineering Project Manager Dated: 05/19/2009

Question 17:

Project Description

The PEA states that the vent pipe conduits would be encased. What would it be encased with?

Response to Question 17:

The below grade vent pipe conduits would typically be encased in concrete.