

Southern California Edison
Presidential Substation Project A.08-12-023

DATA REQUEST SET Presidential ED-03 (Part 1)

To: CPUC

Prepared by: Kendra Heinicke

Title: Estimator

Dated: 05/19/2009

Question 22:

Project Description

For TSPs, provide the diameter that the poles would generally taper to at the top. Would this be different for dead end or riser poles? If so, provide diameter information.

Response to Question 22:

In order to determine the diameter of a specific pole, final engineering is required. However, for this project, SCE anticipates all top diameters, including TSPs, dead end TSPs, and TSP riser poles, to be between 15" and 22".