

Southern California Edison
Presidential Substation Project A.08-12-023

DATA REQUEST SET Presidential ED-03 (Part 1)

To: CPUC

Prepared by: Kendra Heinicke

Title: Estimator

Dated: 05/19/2009

Question 48:

Alternatives

Alternative Subtransmission Routes – Confirm that all of the alternative route segments would be composed of single circuit lines (Route Alternatives 1 and 2).

Response to Question 48:

All alternative route segments would be composed of single circuit lines.