


California Public Utilities Commission		2. Project Description
This page in	tentionally left blank.	
Estrella Substation and Paso Robles Area	2-32	December 2020
Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report		December 2020 Project 17.010



California Public Utilities Commission		2. Project Description
	This page intentionally left blank.	
Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report	2-34	December 2020 Project 17.010





California Public Utilities Commission		2. Project Description
	This page intentionally left blank.	
Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report	2-36	December 2020 Project 17.010




California Public Utilities Commission		2. Project Description
	This page intentionally left blank.	
Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report	2-38	December 2020 Project 17.010


California Public Utilities Commission 3. Response to Comments This page intentionally left blank.









3. Response to Comments




3. Response to Comments





3. Response to Comments






California Public Utilities Commission		3. Response to Comments
	This page intentionally left blank.	







California Public Utilities Commission	3. Response to Comments
This page intentionally left blank.	

2. Project Description

H-54

cont.

- Secondary containment for transformer oil spill control on applicable equipment
- One spare SF₆ filler tank
- Graveled internal access road
- Perimeter security fencing

The fenced portion of the 230 kV substation would be approximately 4 acres in size. A chain-link fence, a minimum of 7-feet-tall, with an additional 1 foot of barbed wire would be installed around the remaining perimeter of the 230 kV substation.

The maximum amount of mineral oil required for the three-phase 230/70 kV transformer would be approximately 16,000 to 18,000 gallons. The mineral oil would be utility grade. The 230 kV substation would be constructed with a concrete secondary containment basin (measuring approximately 45 by 34 by 2.5 feet) to provide mineral oil containment for the transformer and would be designed to allow sufficient freeboard to include the oil volume of the transformer plus the precipitation from a 25-year, 24-hour storm event. Following a storm event, rainwater collected in the containment area would be visually inspected for any contamination before allowing to drain off site through existing drainage swales along Union Road.

The 230 kV substation would connect to existing power and telecommunications located on an existing distribution pole at the northeast corner of the substation site along the edge of Union Road. Electricity would be used for construction (i.e., power construction trailers, lighting, and small hand-held machinery or tools) and operation back-up station service power. The electric power and telecommunication circuits (telephone and T1, either copper or fiber) would be brought to the 230 kV substation on either overhead distribution poles or underground conduits. If overhead, up to six approximately 40-foot-tall wood distribution poles may be constructed between the existing distribution pole and the 230 kV substation. The poles would be direct embedded up to approximately 6 feet. If undergrounded, the back-up power and communications would be brought into the 230 kV substation using up to three underground conduits.

230 kV Transmission Interconnection

The 230 kV transmission line interconnection would be owned and operated by PG&E. It would connect the existing 230 kV transmission line to Estrella Substation in two separate locations: a northern and a southern interconnection (refer to Figure 2-11). The 230 kV interconnection structures include LSTs (lattice steel tower) similar to the existing 230 kV transmission line towers. Figure 2-14 shows a representation of the LSTs to be used for the 230 kV interconnection.

The northern interconnection into Estrella Substation would begin with the replacement of an existing 230 kV LST approximately 200 feet to the northeast along the existing 230 kV transmission line alignment. From there, the northern interconnection would continue southwesterly within the existing 230 kV alignment for approximately 60 feet until reaching a new LST. From this point, the northeasterly interconnection would head southeasterly for approximately 180 feet to a new LST. From this tower, the northern interconnection would head southwesterly, terminating at the northerly 230 kV pulloff structure within Estrella Substation.

2-49

Estrella Substation and Paso Robles Area Reinforcement Project Administrative Draft Environmental Impact Report

2. Project Description

H-54 cont. The southern interconnection would leave the southerly 230 kV pulloff structure within Estrella Substation, heading southwesterly for approximately 60 feet to a new LST. From this tower, the southern interconnection would head northwesterly for approximately 180 feet to a new LST located in line with the existing 230 kV alignment. From this point, the southern interconnection would follow the existing 230 kV alignment approximately 60 feet southwesterly to a new LST. This final tower would interset in the existing 230 kV conductor and complete the 230 kV interconnection.

The six 230 kV interconnection towers would each be mounted on four individual concrete pier foundations, and their base footprint would vary from 25 by 25 feet to 27 by 20 feet. These towers would be configured with six non-reflective, gray porcelain or clear glass insulator strings to support three individual conductors. Three conductors would be installed on each side of the towers and would be arranged in a vertical configuration. New and replacement LSTs within the existing easement would be configured to carry the existing six individual conductors. The overhead conductor would be attached to the new LSTs using non-reflective, gray porcelain or clear glass insulator strings. Structures and conductors would be installed with separation distance and ground clearance in accordance with CPUC General Order (G.O.) 95.


70 kV Substation


The 70 kV substation would be owned and operated by PG&E. The proposed configuration of the 70 kV substation (general arrangement and profile view) is shown in Figure 2-15 and Figure 2-16. The tallest structures within the 70 kV substation, other than the poles supporting the 70 kV power lines, would be the dead-end structures, which are approximately 37 feet high and 28 feet wide.


The following major electrical equipment would be located within the fenced area of the 70 kV substation in the proposed configuration:

- Two 70 kV aluminum buses
- Two 70 kV bus voltage transformers
- Seven line voltage transformers
- Station service voltage transformer
- Eleven 70 kV group operated air break switches
- Five 70 kV SF₆ insulated circuit breakers
- Nine 70 kV dead-end steel structures
- Three 70 kV lightning surge arresters
- A protection and control enclosure measuring approximately 16 feet wide, 96 feet long, and 11 feet tall would be installed on a concrete pad measuring about 3 feet deep. The exterior of the control enclosure would have an air conditioning unit installed to protect electronic components.

Estrella Substation and Paso Robles Area Reinforcement Project Administrative Draft Environmental Impact Report 2-50







California Public Utilities Commission 3. Response to Comments This page intentionally left blank.

H-54

cont

California Public Utilities Commission

2. Project Description

In addition to the electrical equipment, the 70 kV substation would include the following infrastructure:

- Dark sky lighting⁸ and signage
- Battery enclosure
- Paved internal access road
- Concrete skimmer/weir
- Perimeter security fencing

The fenced portion of the 70 kV substation would measure approximately 3.5 acres within the parcel acquired from HWT. An approximately 8-foot-tall chain-link fence with additional 1-1/2 foot of barbed and concertina wire would be installed around the remaining perimeter of the 70 kV substation.

The 70 kV substation would not store mineral oil. A concrete skimmer and weir device (flow measurement device) would be constructed at the southeast corner of the substation. This concrete device settles and collects sediment that is washed down by stormwater before it is discharged from the substation.

2.3.2 70 kV Power Line

The new 70 kV power line and reconductoring segments would use a combination of tubular steel poles (TSPs) and light-duty steel poles (LDSPs) for support. LDSPs would have a surface treatment designed to render the appearance of a natural weathering of a wood pole. Figure 2-17 shows typical drawings of each structure type.

Power line structures would vary in height depending on their location and purpose, but typically would range between 80 to 90 feet. Table 2-5 contains approximate height range and average height of power line alignment poles by structure type. The approximate distance from the ground to the lowest conductor is 29 feet. In areas where existing metal fences are in close proximity to the power line easement and cannot be replaced with non-conductive fences, wood or composite (fiberglass) poles would be used. These alternative poles may also be used in areas where existing underground utility metal lines are encountered in close proximity to structure locations, such as gas lines.

Both the new 70 kV power line segment and the reconductoring segment would use overhead aluminum electrical conductors, which, when installed, typically have a shiny surface appearance. This "reflective" or "specular" surface can make a power line more noticeable in appearance against the background landscape, and therefore more visible to small aircraft pilots that fly over the area. Observations by PG&E and other utilities indicate that specular conductor transitions to non-specular (i.e., becomes less shiny) in the course of a few seasons after installation. The new conductors would be installed to meet or exceed the minimum separation

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-54

⁸ Refer to footnote 7 above for discussion of dark sky lighting.

H-54 cont. California Public Utilities Commission

2. Project Description

distances and ground clearances in accordance with CPUC G.O. 95 and would meet raptor safety requirements.

A more detailed description of the required structures and the associated conductors for the new 70 kV power line and reconductoring segment is provided below.

New 70 kV Power Line Segment

The new 70 kV power line segment would consist of approximately 7 miles of double-circuit 70 kV power line on a combination of two types of structures: TSPs and LDSPs. TSPs would be utilized for the portion of the line that would be installed within the existing PG&E transmission corridor. In general, the TSPs would be installed adjacent to existing 500 kV transmission line towers, utilizing an average span length of approximately 650 feet. Each TSP would be installed on one individual concrete pier foundation.

The remainder of the new 70 kV power line segment would utilize both TSPs and LDSPs. These structures would typically be used in locations where the new 70 kV power line segment is not parallel to the existing 500 kV transmission line. TSP structures would be installed generally in locations where the alignment changes direction. The route would utilize an average span length of approximately 300 to 500 feet.

Structures along the new 70 kV power line segment would be configured with six individual aluminum conductors, measuring up to 1.25-inch diameter, and an underhung fiber optic cable, measuring up to 0.75 inch in diameter. Three conductors would be installed on each side of the structures and would be arranged in a vertical configuration. The overhead conductor would be attached to the structures using six post insulators or insulator strings (three per circuit) for tangent configurations, and up to 12 insulator strings (six per circuit) for dead-end configurations.

Reconductoring Segment

Reconductoring and pole replacement would occur on approximately 3 miles of single-circuit 70 kV power line using a combination of TSPs and LDSPs. LDSPs would typically be used in locations where the alignment is generally straight, and either guyed LDSPs or TSPs would be used in locations where the alignment changes direction or where distribution tap spans are supported on line structures.

Anchors and guy wires would be attached to LDSPs and/or wood poles in locations where additional stability is required to support the conductor tension. The new replacement poles would typically be installed within 10 feet of the existing poles, which would result in a typical pole span length of approximately 300 feet.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report

2-55

⁹ A guy is a tensioned cable designed to add stability to a free-standing structure. One end of the guy is attached to the structure, and the other is anchored to the ground at some distance from the pole or tower base. The tension in the diagonal guy-wire, combined with the compression and buckling strength of the structure, allows the structure to withstand lateral loads such as wind or the weight of cantilevered structures.

2. Project Description

Replacement poles along the reconductoring segment would be configured to continue to carry three existing aluminum conductors, measuring about 1.25 inch in diameter, and an underhung fiber optic cable, measuring up to 0.75 inch in diameter. The conductor would be attached to the poles using three insulators for tangent configurations and six insulators for dead-end configurations.

H-54 cont.

Distribution Lines and Common Neutral

In locations where existing distribution lines are located in close proximity to the 70 kV power line alignment, the distribution conductors may be collocated on the power line structures. The existing conductors would typically be transferred to the new pole line as a distribution underbuild; however, in locations where the existing conductors are not able to be transferred, they would be replaced with an equivalent conductor. In addition, to meet PG&E power line design standards, a common neutral would be collocated along the entire length from Estrella Substation to Paso Robles Substation.

2.3.3 Reasonably Foreseeable Distribution Components

Given that new overhead distribution lines are typically supported by 18 poles per mile, the 1.7 miles of reasonably foreseeable new distribution line would require about 31 new wood poles. It is possible that some existing poles also would need to be replaced to support the reconductored circuits. New wood poles would likely be direct-bury poles (not requiring a foundation) and would require approximately 3 square feet of permanent ground disturbance per pole. The 70/21 kV transformer that would be installed within the 70 kV portion of the Estrella Substation as part of the reasonably foreseeable distribution components would include mineral oil and a concrete secondary containment basin.

2.3.4 Ultimate Substation Buildout

The equipment and facilities associated with ultimate substation buildout would primarily be placed within the fence line of the already-constructed Estrella Substation. The anticipated layout of the Estrella Substation at ultimate buildout is shown in Figure 2-18. The additional 230/70 kV transformer under ultimate buildout is assumed to include the same amount of mineral oil (16,000 to 18,000 gallons) as described for the Proposed Project (see Section 2.3.1), and the same secondary containment structure (i.e., designed to allow sufficient freeboard to include the oil volume of the transformer plus the precipitation from a 25-year, 24-hour storm event). The additional 230 kV interconnection is assumed to include similar structures (LSTs) and follow a similar interconnection process to that described for the Proposed Project in Section 2.3.1 under the header for "230 kV Transmission Interconnection." The additional 70/21 kV transformers that may be installed to support additional distribution feeders are assumed to include secondary containment, as necessary to contain spills of any stored mineral oil.


While ultimate buildout of the Estrella Substation could add six additional distribution feeders (for a total of nine from the substation), as well as additional 70 kV power lines, the routes, lengths, and associated characteristics of these components are unknown at this time.


Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-56


California Public Utilities Commission		3. Response to Comments
	This page intentionally left blank.	

California Public Utilities Commission

3. Response to Comments







California Public Utilities Commission 3. Response to Comments This page intentionally left blank.

2. Project Description

1

H-54

cont.

2.3.5 Other Substation Modifications

Minor modifications within five existing area substations would be required for the Proposed Project. These modifications include installation and reconfiguration of system protection equipment and/or adjusting relays, and reprogramming supervisory control and dataacquisition (SCADA) and telemetry equipment. In addition, the fiber optic telecommunications cable extending from Estrella Substation to Paso Robles Substation along the new 70 kV line will require new network and telecommunications equipment at Paso Robles Substation. The modifications would be made within existing substation fence lines at California Flats Switching Station and Morro Bay, San Miguel, and Templeton substations, while minor excavation outside the fence line of Paso Robles Substation may be required for the telecommunication connection. Table 2-6 below provides a summary of the modifications required at each substation.

Table 2-6. Other Substation Modifications Summary

Substation	Improvements
California Flats 230 kilovolt (kV) Switching Station	 Remove outdoor wave trap equipment and existing Morro Bay-California Flats 230 kV protection, and install new protection relays and related equipment within the existing control building. Remove existing relays and install dual-line differential protection relays on the existing Morro Bay-California Flats line to match new Estrella Substation terminal for permissive overreaching transfer tip (POTT) high-speed protection. Install regenerative catalytic oxidizer (RCO) switches, local/remote, and circuit breaker (CB) control through replaced CB relay. Provide breaker failure relay protection.
Morro Bay 230 kV Substation	 Remove wave trap equipment. Remove existing relays and install dual-line differential protection relays at CB 482 to match new Estrella Substation terminal for POTT high-speed protection. Install RCO switches, local/remote, and CB control through replaced CB relay. Provide breaker failure relay protection.
Templeton 230/70 kV Substation	 Install reverse power relay on the existing Templeton 230/ 70 kV #1 transformer banks to prevent the 70 kV system from feeding the 230 kV system.
San Miguel 70 kV Substation	 Remove existing directional overcurrent electro-mechanical relays at CB 22 breaker relay panel.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report

2-60

2. Project Description

H	1-	5	5	1
c	c	1	1	t.

Substation	Improvements
	 Install two line protection relays in CB 22 relay panel to match new Estrella Substation terminal for step-distance protection. Provide breaker failure relay and reclosing relay protection.
Paso Robles 70 kV Substation	 Upgrade the new Estrella-Paso Robles 70 kV power line to meet line ampacity demands of 975A emergency. Upgrade terminal equipment such as insulators, jumpers, and any rigid bus at the breaker to meet 975A ampacity ratings. Remove existing Schweitzer Engineering Laboratories (SEL) 321 and SEL 267 relays at CB 72 breaker relay panel, along with associated auxiliary switch devices. Install two line protection relays in CB 72 relay panel to match new Estrella Substation terminal for step-distance protection. Provide breaker failure relay and reclosing relay protection. Connect new fiber optic line and common neutral into existing substation, including minor trenching outside the fence line. Connection of the fiber optic line requires a shallow trench, measuring 10 to 15 feet in length and a minimum of 24 inches of cover, to be excavated so the fiber optic line can be connected from the last reconductoring

Notes: CB = circuit breaker; kV = kilovolt; POTT = permissive overreaching transfer tip; RCO = regenerative catalytic oxidizer; SEL = Schweitzer Engineering Laboratories

2.4 Easement Requirements

The parcel of land where Estrella Substation would be constructed is under private ownership. An affiliate of HWT has an option agreement to purchase the approximately 20-acre portion of this parcel. Prior to construction, HWT would purchase and hold fee title of this approximately 20-acre area. This area is adequate to accommodate the approximately 15-acre substation facility including all considerations for site grading, equipment laydown and storage, fencing, access and internal circulation, spill and stormwater management, and other operational considerations. Once all of the environmental permits from the applicable siting and regulatory agencies have been obtained, and grading and drainage has been constructed for the entire substation site, HWT would sell PG&E the land necessary for construction of the 70 kV substation and 230 kV interconnection.

The relocated 230 kV tower and three LSTs associated with the 230 kV interconnection would be installed within the existing transmission line easement. Two additional LSTs would be used to

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-61

H-54

cont.

California Public Utilities Commission

2. Project Description

complete the interconnection and would be installed on the parcel that would be acquired for the development of Estrella Substation.

New easements would be acquired for the majority of the new approximately 7-mile-long 70 kV power line segment. The easements would be up to 115 feet wide with the width to vary based on the location of the new power line. When on private property, the easement would typically be 70 feet wide, and the poles would be located in the center of the easement (35 feet on each side). In locations where the poles would be adjacent to a county or city road franchise, new poles may be located on private property ranging from 2 to 7 feet outside of the road franchise, so the easement would be 2 to 7 feet on one side and 35 feet on the other. There may be some locations where the pole line may be located within the road franchise. A list of properties likely to require new easements and/or acquisition is provided in the PEA (see Appendix H to the PEA).

The approximately 3-mile-long reconductoring segment would be mostly located within an existing 30- to 40-foot-wide PG&E easement. Easement documents may be updated in some locations to account for slight variations in the new alignment and pole placement, or to clarify or update existing rights. If PG&E discovers an encroachment in the existing 70 kV power line easement, it would determine whether it is a conflict with the operation of the 70 kV power line, and/or what action to take, if any, after further investigation. Such action might include working with the property owner(s) to remove the conflict or minor relocation of the alignment and potential modification of the structure type.

A new 30-foot-wide easement, approximately 0.6 mile in length, would need to be obtained on private property to the north of the 70 kV substation to connect the reasonably foreseeable new distribution facilities to existing distribution feeders on Mill Road. The reasonably foreseeable new 1.1-mile-long segment of distribution line is planned to be installed within the existing road right-of-way.

2.5 Proposed Project Construction

The construction process, methods, equipment and personnel needs, access, temporary work areas, and schedule for the Proposed Project components are described in the following subsections.

2.5.1 Construction Process and Methods

Substation Construction

Grading and Site Preparation

Construction of the Estrella Substation would follow a typical sequence beginning with survey marking of staging areas and work areas, establishment of the private access road, vegetation clearance, fencing installation, grading, installation of culverts and swales, excavation of foundations, installation of facilities, and cleanup and post-construction restoration. Vegetation removal would be limited to areas within survey-marked boundaries, and would be completed utilizing mechanized equipment. To the extent practical, removed vegetation may be disposed

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-62

2. Project Description

H-54 cont. of at a landfill. Site construction fencing would be installed during the site preparation stage, and would require digging to a depth of 4 feet to install fencing anchors.

Based on preliminary grading design, earthwork activities for the substation are anticipated to result in approximately 68,000 cubic yards of cut and fill, balanced on site to the maximum extent possible. Approximately 16,500 cubic yards of topsoil would be stripped and stockpiled and approximately 4,000 cubic yards of the stockpiled topsoil would be used during restoration, with the balance removed from the site. Generally, grading and excavation would be accomplished in a phased approach. Earthwork activities (e.g., grading, excavation) would be completed to meet project design specifications and match proposed grades, considering the geotechnical conditions at the site. Maximum excavation depths would occur on the transmission portion of the site and at the steel dead-end structures in the 230 kV substation.

Geotechnical borings were performed in the vicinity of the substation site. The borings showed predominately gravel, clay sand and decomposed granite, which can be excavated. It is anticipated that these materials can be excavated using conventional earth-moving equipment. While not expected due to the clay soil, in the event there are areas where bulldozers and backhoes are not able to remove the material, scraping, ripping, drilling, hammering, and cutting may be used to break up the material into manageable pieces. Blasting is not anticipated.

During earthwork, soils and other surficial deposits that do not possess sufficient strength and stability and/or resistance to erosion of support structures, would be removed from the work area. No contaminated soils are expected on this site due to the long-term vineyard use of the site. All clean spoils excavated for the project would be used on site to balance cut and fill calculations, as feasible. All spoils that are not useable and/or reveal contamination, as determined through testing and/or based on visual appearance, would be sent to a properly licensed landfill facility. All recyclables would be taken to a licensed recycle facility, and all refuse would be taken to the Paso Robles Landfill or other suitable landfill facility. Topsoil reuse is not feasible within the fenced substation area; however, topsoil would be conserved at exterior temporary work areas where applicable.

Material that requires processing for construction of Estrella Substation would be mechanically processed on site to achieve a maximum particle size and distribution suitable for conventional placement in engineered fills. In addition to general earth-moving quantities, approximately 4-6 inches of surface gravel would be required to be imported and installed within the substation footprint and along the access road. Additionally, gravel would be placed in the substation staging areas.

Below-Ground Construction

Following site preparation, construction of the substation equipment foundations (consisting of drilled pier, mat, and pad type foundations), underground ducts, and the grounding grid would commence. Foundation construction excavation would be accomplished primarily by backhoes and drill rigs. Forms, reinforcing steel, and concrete would then be installed, as appropriate, to build the foundations for substation equipment and the control enclosures. Structure and equipment foundations would be excavated to an approximate depth of between 10 and 25 feet. Actual depths would depend on the equipment to be installed. Concrete pouring would be required to construct the foundations. Underground bundled polyvinyl chloride (PVC) conduit ducts and below-grade cable trench would be constructed within the substation pad for the

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-63

	California Public Utilities Commission		2. Project Description
H-54 cont.	power and control circuits.		
	Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report	2-64	December 2020 Project 17.010

2. Project Description

H-54

Above-Ground Construction

Power lines and distribution circuits would be connected inside the substation after substation structures and equipment are installed. Control and protection wiring would be completed during above-ground structure installation. All equipment would be tested after installation and all wiring is landed, and before placing the substation in service. Equipment would be placed in service once individual power lines and circuits are ready to be energized and have been tested.

It is anticipated that all major electrical and substation equipment would be delivered to each substation site and placed directly on foundations and footings once all concrete footings have cured. All new components would be delivered to the site using a flatbed truck and positioned using a small crane or forklift. All equipment including breakers, bus supports, insulators, bus and switches would be installed or anchored into final position, grounded, and if required wired back to the control house. The control house will be delivered and installed on concrete piers. The control house building will then be ready for the installation of protective relay panels, batteries, AC and DC load centers, SCADA and telecommunication hardware and air conditioning systems. Final equipment testing and commissioning would then be performed in the substation and then in conjunction with PG&E's new and existing facilities.

Access Driveway and Interior Road Construction

Access road construction would begin by excavating to a depth of approximately 2 feet at the intersection with Union Road, increasing to 17 feet deep for the remainder of the road. Next, the road would be graded and compacted in accordance with engineering standards and geotechnical requirements. Following initial compaction, road base would be imported, distributed on site, and final compacted. Finally, conventional paving equipment would be used to distribute the asphalt road material along the main access route and driveway aprons. Paving of the access road would occur after major construction at the substation site is completed and all heavy equipment is removed from the site.

230 kV Transmission Interconnection Construction

Installation of the 230 kV transmission interconnection to Estrella Substation would require a number of activities including setting the new tower foundations, tower assembly, and partial erection for the new towers. Construction activities would include the following:

- Adjacent to the new 230 kV substation, a temporary connection (commonly referred to as a "shoo-fly") would be installed to ensure that the existing 230 kV transmission line remains in service. Near the existing tap structures at each location, one to three (depending on the orientation of the conductor wires) wood poles would be placed in the ground without foundation and guy-wired for stability. The temporary structures would connect the conductors as necessary for the existing 230 kV transmission line to remain in service.
- The first circuit on the existing double-circuit 230 kV transmission line would be cleared, and the phase conductors would be moved off the two existing LSTsonto the temporary poles. The first circuit would then be re-energized.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-65

2. Project Description

H-54

cont.

- The second circuit on the existing double-circuit 230 kV transmission line would be cleared, and the erection and interset of two new LSTs would be completed. The phase conductors for the circuit would be dead-ended and temporary jumpers would be installed.
- The OPGW at each new tower would be secured, an existing LST would be removed, and two LSTs would be installed for the Estrella Substation interconnection.
- The second circuit on the existing 230 kV transmission line would be re-energized and the first circuit cleared. The existing phase conductors would be transferred from the temporary poles to the new towers. The phase conductors on the new towers would be dead-ended and permanent jumpers installed; the phase conductors would be reattached, and the first circuit would be re-energized.
- The temporary poles and anchors used for the shoo-fly would be removed.

The 230 kV interconnection LSTs would be installed on concrete pier foundations. Large augers and drill rigs would complete the required excavations and, if necessary, a reinforcing steel rebar cage would then be lowered into the excavation. An approximately 2-foot-tall form would be constructed. Concrete would then be poured to fill the excavation. Each completed foundation would be left to cure for 7 to 14 days. Typical foundation dimensions for the 230 kV interconnection are included in Table 2-7.

Table 2-7. 230 Kilovolt Interconnection Structure Foundation Summary

Foundation Type	Quantity	Approximate Diameter (feet)	Approximate Depth (feet)	Approximate Excavation Volume per LST (cy)	Approximate Concrete Volume per LST (cy)
230 kV Lattice Steel Tower	6	3–4	13–16	2.6-6.1	3.4–7.4

Notes: cy = cubic yards

Each LST is comprised of multiple steel members that are connected together with hardware to form the tower. Installation of the tower would begin with the assembly of the tower in one or more sections. This assembly process may occur at one of the staging areas or within the work area at the individual tower's location. Once the first section of the tower is complete, it would be placed onto the cured concrete foundation using cranes and secured using the appropriate hardware. This process would be repeated for any additional sections of the tower until it is complete. Insulators and additional hardware would be added to the tower using a bucket truck and cranes. In areas of difficult terrain, a helicopter may be used to assist with the tower installation process. If applicable, the existing conductor would then be attached to the new tower hardware.

As part of the 230 kV interconnection work, an existing LST would be removed and then replaced by a new LST in a slightly different location. The LST would be removed by disassembling the tower into three sections and lowering each section using a crane, or taking it down in one lift using a crane. Helicopters may be used to assist in the tower removal process.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-66

2. Project Description

H-54 cont. Following disassembly of the tower, its segments would be transported for reuse, recycling, or disposal at an approved facility. Once the LST has been removed, the associated concrete pier foundations would be jackhammered to approximately 3 feet below grade. The remaining void would then be backfilled with native soil saved from other excavations in the surrounding area and returned to its original contours, to the extent feasible, or in accordance with prearranged landowner agreements.

Telecommunications and Power Line Interconnection Construction

For the 230 kV substation, the back-up electric power source and telecommunication lines would be brought to the site either on overhead distribution poles or in underground conduits. If overhead, up to six wood poles (distribution poles, approximately 30 feet tall) may be constructed within the substation permanent disturbance area. The poles would be direct-embedded up to approximately 6 feet. If undergrounded, the back-up power and communications could be brought into the 230 kV substation in up to three underground conduits. Open trenching and/or horizontal directional drilling (HDD) may be used to install the conduits for power and communications cables. Any directional drilling pits would occur within the permanent or temporary disturbance areas. Depending on the voltage level and distance from the PG&E distribution line, either a pole-mounted transformer (on a PG&E pole), located along the existing distribution line that intersects the utility corridor, or a pad-mounted transformer, located adjacent to the control enclosure, would be installed.

For the 70 kV substation, the OPGW cable would be cut at the existing LST that is to be removed. The OPGW cable would then be rolled back to the first LST located both northeast and southwest from where the cable is to be cut. The cable would then extend down a tower leg at each of the towers and enter into a pull box. The pull boxes located near the bases of the existing towers and pull boxes installed near the fence line of the substation would be connected by underground conduit. The OPGW cable would transition on the tower legs to an underground fiber optic duct cable and then travel through 4-inch PVC conduit until terminating inside the 70 kV substation control house. Approximately 3,000 feet of new 4-inch conduit would be installed to complete the telecommunications system extension.

The conduit would be installed using open trenching methods of construction, HDD techniques, or a combination of the two. The actual method of installation would be determined during final design.

Open Trench Method

Excavators and other earth-moving equipment would be used to establish trenches for telecommunication lines, which typically range between 36 and 60 inches in depth, and 24 and 36 inches wide. Depths may vary depending on soil stability, the presence of existing substructures, and discussions with adjacent property owners/farmers.

Once a trench is excavated, large-diameter gravel would be applied to the bottom of the trench to create a level bed for the conduit and act as a French drain. PVC conduitwould then be placed in the trench and a granular substrate (typically sand) level would then be layered around the conduits for additional protection and stability. The excavated material would be used to backfill the remainder of the trench. During backfill operations, "warning tape" would be placed at least 12 inches above the conduit. Once

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-67

2. Project Description

the trench is backfilled, the area would be compacted using portable compaction devices.

Horizontal Directional Drilling Method

H-54 cont. HDD is a highly specialized boring technique that may be used to install conduits beneath the existing vineyards in the vicinity of the telecommunications system extension. The HDD technology uses a hydraulically powered horizontal drilling rig supported by a drilling mud tank and a power unit for the hydraulic pumps and mud pumps. A variable-angle drilling unit would initially be adjusted to the proper design angle for the particular drill.

The first step would be to drill a fluid-filled pilot bore. The first and smallest of the cutting heads would begin the pilot hole at the surveyed entry point in the entry pit. The first section of the drill stem has an articulating joint near the drill-cutting head that the HDD operator can control. Successive drill stem sections would be added as the drill head bores along the specified route. The drill head would then be articulatedslightly by the operator to follow a designed path under the crossing and climb upward toward the exit point. Once the pilot hole is completed, a succession of larger cutting heads and reamers would be pushed and pulled through the borehole until it is the appropriate size for the 4-inch conduit. Using this method, the conduit would be installed up to 10 feet under the existing grade.

An entry pit and an exit pit are required for each HDD to contain the drilling mud. In general, the work area required on both the entry and exit sites would be approximately 50 by 50 feet. A non-toxic, water-based lubricant containing water and bentonite clay, referred to as drilling mud, would be used to aid the drilling, coat the walls of the borehole, and maintain the opening. During the bore, drilling mud would be pumped under high pressure through the drill stem to rotate the cutting head and return the soil cuttings to a pit at the surface entry point. No additives considered hazardous according to federal and state laws would be used during the HDD process. The drilling mud would be received in an approximately 6-foot by 6-foot pit.

The drilling mud returned back through the bore-drilled hole would be pumped from the entry and exit pits to a processing/shaker unit where the soil cuttings are removed, allowing the drilling mud to be reused. It is anticipated that the majority of the drilling mud would be recycled by the drilling contractors and used on subsequent projects. Any excess clean drilling mud would be disposed of at an appropriate waste facility.

Once the borehole reaches the correct diameter, the conduit would be pulled through the borehole until it surfaces on the other side. The installed conduit would then be connected to adjacent splice boxes and/or other sections of conduit, and the entry and exit pits would be backfilled.

In order to facilitate the pulling and splicing of the cables, an underground pull/splice box would be installed at the base of an existing or newly installed structure. All pull/splice boxes used for the project would be pre-cast polymer concrete and traffic-rated boxes, measuring approximately 3 by 5 feet, as shown in Figure 2-19. These splice boxes would provide access during operations to the underground cables for maintenance, inspection, and repair.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-68

2. Project Description

H-54 cont. An excavator or backhoe would be used to excavate a 5-foot-deep cavity near the base of the pull/splice box, measuring approximately 4 by 6 feet. The pull/splice box would be delivered to the project site on a flatbed truck and lowered into place using a small truck-mounted crane. The pull/splice box would then be connected to the underground conduits before being covered with at least 2.5 feet of compacted fill. The area around the pull/splice box would be restored with native soil saved from the initial excavation.

After installation of the conduit, the project proponents would install the communication cable in the conduits. Each cable segment would be pulled into the conduit, spliced at each splice box, and terminated at the transition where the lines convert to overhead. To pull the cable through the conduit, a cable reel would be placed at one end of the section and a pulling rig would be placed at the other end. A large rope would then be pulled into the conduit using a fish line, and attached to the cable-pulling eyes. The cable-pulling eyes would then be attached to the cable and the cable is then pulled through the conduit. A lubricant would be applied to the cable as it enters the conduit to decrease friction during pulling.

70 kV Power Line Construction

Site Preparation and Grading


Power line installation would begin with the clearing of the work areas at the location of each structure using a mower and/or backhoe. If necessary, minor grading may be conducted to develop a flat, safe area.

Crossing Structure Installation

Crossing structures would be installed to protect existing roadways and other facilities from sagging conductors during construction. PG&E would auger an approximately 2-foot-diameter, 8-foot-deep hole within each crossing structure work area to facilitate the crossing structure installation. The temporary wood poles would then be placed in the excavations by using a small crane, line truck, or loader, and secured by backfilling and compacting the excavated material into the remaining void. In areas where crossing protection may be short in duration or of low risk, equipment (e.g., line trucks or cranes) may be used in place of crossing structures to shield the crossing from potentially sagging conductors. Crossing structures may also be mounted on line trucks rather than in the ground.

Netting may be used if required for crossing over major roads. A crossing structure would be installed on both sides of the road and netting would be strung between the structures. When crossing SR-46, an additional structure may be needed in the median to help support the netting over the highway. The crossing structure would be installed according to encroachment permit requirements.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-69



2. Project Description

Power Line Structure Installation

The 70 kV TSPs would be installed on concrete pier foundations. Large augers and drill rigs would complete the required excavations and, if necessary, a reinforcing steel rebar cage would then be lowered into the excavation. An approximately 2-foot-tall form would be constructed, and concrete would then be poured to fill the excavation. Each completed foundation would be left to cure for 7 to 14 days. LDSPs would be direct-embedded and would not require a foundation. Table 2-8 shows a summary of the typical power line structure foundation dimensions.

H-54 cont.

Table 2-8. Power Line Route Structure Foundation Summary

Foundation Type	Quantity	Approximate Diameter (feet)	Approximate Depth (feet)	Approximate Excavation Volume (cy)	Approximate Concrete Volume (cy)
70 kilovolt (kV) Light Duty Steel Pole	110	3.0	12.0-20.0	3.1–5.2	0
70 kV Tubular Steel Pole	47	4.5-5.0	16.5-18.0	7.9–10.9	9.7–13.1

Notes: cy = cubic yards; kV = kilovolt Source: NEET West and PG&E 2017

Typical equipment used for power pole installation includes truck-mounted augers and drills to excavate the holes. When foundations are needed, concrete trucks supply and pour concrete into installed holes. Cranes are used to lift and place new poles/towers into the newly installed holes or foundations. Cranes and/or bucket trucks lift workers into elevated positions to work on newly installed poles or towers. Crew cab and pickup trucks are used to transport workers and tools to each installation site. Water trucks and portable water tanks are used to minimize fugitive dust during excavation and restoration activities.

New TSPs, along with crossarms, insulators, and hardware, would be delivered to structure sites in two or more sections using a flatbed truck and assembled on site. The crossarms would be attached, the pole would be placed onto the cured concrete and anchor bolt foundation using cranes, and the pole would be secured using the appropriate hardware. If the pole is delivered in multiple segments due to access restrictions or other engineering considerations, the segments would be placed in order and secured using hardware. In areas of difficult terrain, poles may be delivered and assembled on their foundations using a helicopter. Once the pole is installed, additional hardware would be added to the crossarms using a bucket truck. If applicable, the existing conductor would then be attached to the new TSP hardware. Excess soils would be removed to the staging area and then covered, tested, and disposed of, as required.

Similar to TSPs, LDSPs, as well as crossarms, insulators, hardware, and any wood poles, would be delivered to structure sites in flatbed trucks. As noted above, the LDSPs would be embedded directly into the ground and would not require a separate concrete foundation. Installation includes excavation of an up to 3-foot-diameter, 12- to 20-foot-deep hole. Following the excavation process, the poles, insulators, and hardware would be assembled. The poles would

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report

2-70

2. Project Description

H-54 cont. then be placed into the excavated hole using line trucks or cranes, the remaining void would be backfilled, and the backfill area would be compacted using portable compacting machinery. Once the pole is embedded and the backfill area is compacted, additional hardware may be added to the pole using a bucket truck. If applicable, the existing distribution conductor would then be attached to the new LDSP hardware.

Existing Structure Removal

Following the transfer of the existing distribution and 70 kV conductors to the new poles along the reconductoring segment or transfer of the existing distribution line to the new 70 kV power line segment poles, crews would remove existing distribution and power line poles and hardware using cranes, aerial man lifts, and/or helicopters. In the new 70 kV power line segment, approximately 40 existing distribution poles would be removed. In the reconductoring segment, approximately 50 power line poles would be replaced and about 12 existing distribution poles would be removed or replaced. Old wood poles would simply be lifted out of the ground using mechanical equipment. Removal of steel poles would occur by excavating an area around the pole to a depth of approximately 2 to 4 feet, or deeper if requested by private property owners. The pole would then be cut off and the remaining base would be buried in place.

All removed poles would be transported off site to the staging area or to the PG&E Service Center for reuse evaluation. Bases of the poles would then be removed by excavating the area around the base. The remaining void would then be backfilled with native soil saved from other excavations in the surrounding area. The site would be returned, as near as practicable, to its original contours (or in accordance with prearranged landowner agreements, where applicable).

Electric Distribution Line Outages

During construction, sections of distribution lines that would cross the project or would be collocated on the new 70 kV power line segment may be temporarily taken out of service. As part of its normal operating procedures, PG&E's Distribution System Operations group would coordinate taking the distribution lines out of service (i.e., taking a clearance). The Distribution System Operations group would assess how to accomplish the clearances, identify where and when clearances may occur, notify customers being served by the distribution line that power outages could occur, manage the clearances, and retain balance in the system by routing power to minimize customer outages.

To accomplish the clearances and maintain balance in the system, the Distribution System Operations group must operate switches at locations along the distribution lines being taken out of service, or along other distribution lines that may be affected by taking a line out of service. Sometimes the switches are thrown at a central location such as a substation, and sometimes switches are operated remotely by System Operations. Other times, the System Operations team must physically drive to a field location and operate the switch manually. Because switches are often located above ground level on distribution poles, bucket trucks are used to enable a worker to reach the switches. Operating a switch takes a matter of minutes and the worker would return to other work once the switching is completed. These distributionswitching activities take place throughout PG&E's service territory and are an integral part of PG&E's ongoing operational activities.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-71

2. Project Description

H-54 cont.

Conductor Installation

The new pole line conductor installation process would begin by temporarily attaching sheaves and rollers to the lower end of the insulators to allow the conductor to be pulled along the line. A rope would then be pulled through the rollers from structure to structure. In instances where terrain is difficult, or the use of a bucket truck or aerial man lift is not feasible, this may be accomplished using a helicopter. Once the rope is in place, it would be attached to a steel cable and pulled back through the sheaves. The conductor would then be attached to the steel cable and also pulled back through the sheaves and into place. Pulling would be completed using conventional tractor-trailer pulling equipment located within one of the substations or within designated pull sites located along the alignments. The pulling through each structure would be done under a controlled tension to keep the conductor elevated and away from obstacles.

The reconductoring installation process would be completed in a similar manner to the new pole line conductor; beginning by temporarily attaching sheaves and rollers to the lower end of the insulators, and putting the old conductor into the roller. The new conductor would then be attached to the old conductor and pulled through the sheaves and into place using similar conventional tractor-trailer pulling equipment and methods, as described above.

After the new conductor has been pulled into place, the sag between the structures would be adjusted to a pre-calculated tension. The conductor would then be attached to the end of each insulator, the sheaves would be removed, and vibration dampers and other hardware accessories would be installed. The existing 12 kV distribution line would be transferred from the existing poles to new poles, where applicable. Old line would be removed from the sites on a line truck with trailer.

Reasonably Foreseeable Distribution Components

Construction of the reasonably foreseeable new distribution line segments would follow a similar process to the 70 kV power line construction, but on a smaller scale. No site preparation or grading would be required for the distribution line construction and reconductoring. Distribution poles would be direct-embedded and, once installed, conductors would be strung using reel trailers pulled behind trucks that park in flat areas. No outages would be required for construction of the new distribution line segments except to tie into the existing circuits. During reconductoring, any outages of the existing distribution lines should be minimal and limited to the close proximity to where the work is being done.

The work within the 70 kV substation to establish the reasonably foreseeable distribution feeders would follow a similar process to that described above for the Proposed Project (see "Below-Ground Construction" and "Above-Ground Construction"). This work would require some ground disturbance associated with construction of equipment foundations, but this would take place within the fence line of the already-constructed Estrella Substation. Equipment foundations would likely include drilled pier and pad type foundations. Trenching would likely be done to install additional conduits to route 21 kV cables and control cables between equipment and the existing control building. Once the 70/21 kV transformer is in place, a concrete curb would likely be poured to create a containment basin, then mineral oil would be delivered to complete the final assembly of the unit. The 70/21 kV transformer would be constructed with secondary containment design for oil containment in the event of a spill.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-72

2. Project Description

H-54

cont.

All equipment would be tested after installation and wiring, and before placing in service. Equipment would be placed in service once individual circuits are ready to be energized and have been tested outside the substation.

Ultimate Substation Buildout

Ultimate buildout of the Estrella Substation would follow a similar process to that described for the Proposed Project. Specifically, new equipment (e.g., transformer, breakers, switches, etc.) within the 230 and 70 kV substations would be installed, tested, and commissioned in a similar manner to that described under "Below-Ground Construction" and "Above-Ground Construction" for the Proposed Project. Some ground disturbance would be required for constructing the equipment foundations and substation wiring, but this would occur within the fence line of the already-constructed Estrella Substation. Construction of the additional 230 kV interconnection is assumed to follow a similar process to that described above for the Proposed Project, under the heading "230 kV Transmission Interconnection Construction".

2.5.2 Construction Temporary Work Areas and Access

Construction of the Proposed Project would require establishment of temporary work areas, such as staging areas, structure work areas, conductor pull and tension sites, and helicopter landing areas. Construction of temporary access roads also would be required. While locations for temporary work areas and access roads may need to be adjusted as part of final engineering and at the time of construction due to land use changes, avoidance of unanticipated environmental impacts, and other factors, approximate locations of temporary works areas are shown in Figure 2-6 and Figure 2-7. Table 2-9 provides a summary of the approximated temporary work area/disturbance area requirements for construction of the Proposed Project.

Table 2-9. Proposed Project Temporary Disturbance Areas

Temporary Work Area	Anticipated Site Preparation	Total Approximate Area (Acres) ¹
Estrella Substation		
Substation Work and Staging Areas	Vegetation removal and grading, including grape vines (and roots) and grasses.	0.09
70 kV Power Line Aligr	nment	
Staging Areas ²	Vegetation removal may be required, temporary fencing and gates would be installed, gravel would be installed, and temporary power would be supplied by a distribution tap or generator.	35.3
Pole Work Areas ³	Vegetation removal and minor grading may be required.	44.4
Crossing Structure Work Areas	Vegetation removal may be required.	1.1
Pull and Tension Sites	Vegetation removal may be required.	10.9

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report

2-73

2. Project Description

H-54

Temporary Work Area	Anticipated Site Preparation	Total Approximate Area (Acres) ¹
Landing Zones	Sites would be leveled free of obstacles and debris.	1.4
Access Roads	Existing unpaved roads may be improved within the existing road. Improvements include minor grading/blading and the placement of dirt and/or gravel. Overland access may require vegetation removal.	20.1
Reasonably Foreseeabl	e Distribution Components ^{4, 5})
Distribution Pole Work Areas	Vegetation removal may be required.	1.8
21/12 kV Pad- Mounted Transformer Work Areas	Vegetation removal and minor grading may be required.	1.5

Notes: kV = kilovolt; LDSP = light-duty steel pole; LST = lattice steel tower; TSP = tubular steel pole

- 1. Acreage totals do not account for overlapping work areas.
- 2. The Golden Hill Industrial Park Staging Area may be replaced with an approximately 10-acre staging area located on Paso Robles Municipal Airport property.
- Includes work areas for new and replacement LSTs, TSPs, LDSPs, work areas required for removal of existing poles, and existing and new distribution poles.
- 4. If construction of the reasonably foreseeable distribution components occurs at the same time as the substation and 70 kV project components (not currently predicted), the staging area in the Golden Hill Industrial Park may be used. Otherwise, staging for construction of the distribution components may occur at the PG&E yard at Templeton Service Center.
- Work within the Estrella Substation (installation of 70/21 kV transformer and associated equipment) for the reasonably foreseeable distribution components would not result in any new temporary disturbance outside of the substation fence line.
- Specific temporary impact acreages associated with the additional 230 kV interconnection that could be installed as part of ultimate substation buildout are currently unknown. However, it is assumed that the additional 230 kV interconnection would be composed of LSTs, similar to the Proposed Project, which require a work area of 200 by 200 feet for each LST.

Source: NEET West and PG&E 2017

Staging Areas

Proposed Project construction would require four main staging areas: two staging areas supporting construction of the 70 kV power line alignment (one of which may also support construction of the distribution components), and two staging areas supporting construction of Estrella Substation. Depending on the timing of construction of the distribution components of the Proposed Project, an existing PG&E yard at Templeton Service Center may also be used. The largest staging area would be the Golden Hill Road Staging Area, which would be approximately 34.8 acres. The other staging area supporting the 70 kV power line construction would be located at Navajo Avenue, and would be approximately 0.5 acre. The two Estrella Substation staging areas

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-74

2. Project Description

H-54 cont. supporting construction of the substation, totaling approximately 1.9 acres, would be located entirely within the 20-acre site..

Staging areas would be used for receiving and staging of materials and equipment, laydown areas, and employee parking. Staging areas would also serve as the assembly point for project personnel, as well as in some cases, the location for temporary, portable bathroom facilities; equipment storage during off-work hours and weekends; materials storage; office trailer staging; and a meeting area, as needed, for project management. For work activities at the substation site and the main staging sites, a temporary overhead service drop (tap) or an underground service (run) would be extended to the sites to provide power if existing distribution facilities are present. If a distribution service from nearby distribution lines is not feasible for the staging area sites, these areas could receive power from temporary, portable generators.

Preparation of the two main staging areas supporting the 70 kV power line alignment would take approximately 4 weeks to complete and would include the following actions and improvements:

- Site leveling and grading;
- Installation of temporary in-ground fencing (if not already present), including 6-to 8-foot-tall chain-link fence, with up to 2 feet of barbed wire around the perimeter of each staging area with locking gates to control access;
- Placement of gravel or equivalent material within staging area to control dust, sedimentation, equipment track-out, and prevention of stormwater runoff leaving the site during rain events;
- Installation of temporary power from portable generators and/or taps to existing distribution lines in the area; and,
- Installation of necessary construction office trailers, sanitary facilities, and storage buildings.

Structure Work Areas

Structure work areas would be established at each new or replacement tower or pole that would be installed as part of the Proposed Project. These work areas would be used to facilitate the tower/pole assembly, erection, and hardware assembly processes. They would also be used to support the conductor installation and/or removal processes. The final tower/pole locations would be determined when engineering is complete and, where feasible, would be adjusted to account for property owner preferences. Structure work areas may also be adjusted to accommodate the final tower/pole locations.

These work areas would typically be centered on the tower/pole location and would vary in size depending on the type of tower/pole being installed. Typical work areas are about 100 feet by 100 feet for LDSPs, 150 by 150 feet for TSPs, and 200 by 200 feet for LSTs. These work areas may be cleared of vegetation and graded, if necessary, prior to their use. Some sites may also require

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-75

2. Project Description

H-54 cont. tree trimming, tree removal, and/or vine removal. Work areas for existing and new distribution poles would typically be about 50 by 50 feet.

Temporary work areas would similarly be required for installation of crossing structures. These work areas would typically measure approximately 40 by 40 feet. Preparation of the site would typically be limited to mowing vegetation, as needed, to minimize the risk of fire. Approximate crossing structure locations for the 70 kV power line are depicted on Figure 2-7.

Pull and Tension Sites

Pull and tension sites, also known as stringing sites, would be used to install conductor on support structures. Pull and tension sites would only be needed for the 70 kV power line (not the distribution line). Conductor installation activities at stringing sites would include pull and tension equipment staging, temporary pole anchor installation, and pulling and tensioning of the conductor. In addition, select pull sites may provide the necessary work area needed for telecom-related activities. Proposed pull site locations are depicted on Figure 2-7.

Pull sites would typically be located within the power line easement and can be spaced between 0.5 and 1 mile apart. In locations where pulling would be required through an angle, or at the start of a new direction of the alignment, the pull site may be located at an angle outside the easement or off the end of an easement corner. Pull sites would typically be 70 feet wide and would range between approximately 120 and 150 feet long. Each stringing site would require about 0.25 acre.

Typical equipment required for pull and tension sites includes pullers, tensioners, cranes, crawlers, water trucks, crew cab trucks, and pickup trucks. Construction crews would access pull and tension sites using rubber tire mounted trucks. Access may be required throughout the easement, away from structure work areas and pull sites, to support pull and tension activities.

All pull sites located outside of paved areas may require vegetation trimming/removal to minimize the risk of fire and, depending on the local terrain, some minor grading may be required to ensure a flat and safe work environment. Depending on the time of year and field conditions at the time of construction, gravel may be applied to help stabilize the ground for equipment use.

Helicopter Landing Zones

Helicopter landing zones may be used during construction for the staging, storage, refueling, and operation of helicopters during construction. While the number and exact locations of helicopter landing zones may change depending on site conditions at the time of construction, six sites have been identified for use during the Proposed Project:

- Landing Zone 1: Paso Robles Municipal Airport;
- Landing Zone 2: Estrella Substation site, south of existing temporary worker residence adjacent to Union Road;
- Landing Zone 3: new 70 kV power line segment site north of Golden Hill Road (may be collocated with a stringing site);

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-76

2. Project Description

H-54

- Landing Zone 4: new 70 kV power line segment site south of Buena Vista Drive;
- Landing Zone 5: reconductoring segment site west of Palo Alto Court (may be used asa staging area instead and may be collocated with a stringing site); and
- Landing Zone 6: reconductoring segment site west of Navajo Avenue (may be collocated with a stringing site).

Approximate locations of these potential landing zones are depicted on Figure 2-7. The two non-airport landing zones would measure about 100 by 100 feet, with a 30- by 30-foot touchdown pad area. Because the identified landing zones are comprised of an airport and two disturbed areas within the Proposed Project area, these landing zones would not require extensive preparation.

Construction Access

Construction crews, materials, and equipment would primarily access the Proposed Project site by using U.S. Route 101 and SR-46, and by traveling along Union Road, Golden Hill Road, or North River Road. In addition to using a system of existing paved and unpaved roads, the Applicants may also grade or mow segments of new temporary unpaved roads, or travel overland to provide access to Estrella Substation and/or pole locations along the new 70 kV power line and reconductoring and pole replacement segments. The new and reconductored distribution line segments would be accessed via an existing dirt road north of the proposed substation site and along other existing paved and unpaved roads (no new access would be needed for construction of the distribution components).

Access to the work sites for workers and equipment would occur using rubber tire mounted vehicles. Some 70 kV poles may also be accessed on foot if sensitive resources preclude the use of heavy equipment. For roads that require improvements for access and equipment delivery, grading could be conducted, if necessary, followed by the addition of temporary rock bedding. Equipment required for this work may include a grader, dump truck for gravel delivery, and a loader or tractor to spread rock. Work along the new 70 kV power line segment would occur from the road shoulder, where feasible.

Permanent and construction access to the proposed substations would be immediately off Union Road on a new private access road. The main access road would be paved and measure about 1,700 feet long and about 20 feet wide. Construction access for the proposed 230 kV interconnection would occur using the same access route being used for substation construction. It is anticipated that access from the substation to the existing 230 kV transmission line would occur using PG&E's existing utility easement, immediately adjacent to the Estrella Substation property boundary.

Helicopter Access and Use

Light-duty and medium-duty helicopters with a maximum payload capacity of approximately 4,000 and 10,000 pounds may be used to assist with the installation of new 70 kV poles and/or conductor installation and removal. Helicopters would primarily be used for such activities in areas along the power line alignment where limited access or local terrain conditions prohibit the work from being conducted by ground-based crews and equipment. Based on preliminary

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-77

2. Project Description

H-54 cont. assessment of the proposed alignment, and for quantitative discussion purposes in the EIR, it is projected that helicopter activities may occur approximately 132 days during the 18-month construction period for the substation and 70 kV power line. It is anticipated that only one helicopter would be used at any one time.

Typical helicopter payloads would include, but not be limited to, poles, sock lines, power line hardware, crewmembers, and equipment. Refueling activities would occur only at the Paso Robles Municipal Airport. Flight paths for helicopters would be from the Paso Robles Municipal Airport and would generally extend directly to and along the power line easement. Helicopter operation would be planned to avoid sensitive receptors. Hours of operations for helicopters would generally be the same as those for construction, 7:00 a.m. to 5:30 p.m., Monday through Friday, and would include Saturdays when needed. In some cases, residents may need to relocate from their home temporarily during helicopter activities; this is discussed further in Section 4.14, "Population and Housing."

2.5.3 Construction Workforce, Equipment, and Schedule

Different phases of the construction process would require varying numbers of construction personnel. On a typical workday, about 12 to 15 construction crewmembers would be working at Estrella Substation. Similarly, about 10 to 15 construction crewmembers would be working on the installation and/or removal of power line structures and on reconductoring activities. During pulling activities, a larger work team would be required to complete the various work stages. Typically, this activity would require about 30 workers, for short periods of time. During construction of the power line segment, up to four crews of approximately six workers each would be working at any one time. Project equipment, personnel requirements, and task duration by construction activity are presented in Table 2-10.

Construction would typically occur 6 days per week (Monday through Saturday) throughout the duration of construction, although water trucks may be operated on Sundays for fugitive dust control in compliance with the Construction Activity Management Plan. Daily work hours would generally be 10 hours per day with construction typically occurring between 7:00 a.m. and 5:30 p.m. Occasionally, work may occur during the evening hours for activities such as monitoring the substation foundation curing process, and testing and commissioning the new substation components. However, such activities would not normally generate loud nose. Nighttime work may also be required (e.g., when electrical clearances are available or for safe completion of a construction procedure).

2.5.4 Construction Power, Water Use, and Domestic Supply Services

Electric power required for construction of the Estrella Substation would be supplied by tapping into the existing power lines adjacent to the substation site. Small generators may also be used to supply temporary power during construction at the substation site.

The proposed substation site is not located within a water district or sewer service area. Water required for construction may come from several sources, including a private well located adjacent to the western edge of the substation site, a municipal water source, delivery by water trucks, or Lake Nacimiento, which is located northwest of Paso Robles. Another potential water source for construction would be recycled water from the City's newly upgraded wastewater treatment plant.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-78

California Public Utilities Commission

2. Project Description

Table 2-10. Preliminary Construction Workforce and Equipment Use, and Approximate Task Durations

H-54 cont.

Proposed Project Task	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Dates
Estrella Substation		<u> </u>		**	
230 kV Substation			~		
Access Roads	Workers	10	Skip Loader	2	Month 1
	1-Ton Crew Cab Flat Bed, 4 x 4	1	Water Truck	1	
	Dump Truck	2	-	-	
Site Work Area Preparation	Workers	10	Roller	2	Month 1-2
Mobilization	Bulldozer	1	Grader	1	
	Articulating Dump Truck	4	Tandem Axle Dump Truck	2	
	Scraper	1	Water Truck	2	
	Rubber Tire Loader	1	Pickup Truck	1	
Fence and Gate Installation	Workers	5	3-Ton Flat Bed Truck	1	Month 2
	½-Ton Pickup Truck, 4 x 4	1	Bobcat	1	
	1-Ton Crew Cab Flatbed, 4 x 4	1	Water Truck	1	
Foundation Construction	Workers	2–12	Water Truck	1	Month 2-3
	Hole Digger	1	Pickup Truck	1	
	Backhoe/Dozer/Excavator	1	Crane or Boom Truck	1	
Ground Grid Conduit Installation	Workers	5	Water Truck	1	Month 3-4
	Trencher	1		_	
Steel Bus Erection	Workers	5	Aerial Manlift	1	Month 4
	Boom Truck	1	Water Truck	1	

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-79

Proposed Project Task	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Dates
Install Yard Rock	Workers	8	Dump Truck	1	Month 4-5
	Bobcat	1	Water Truck	1	
Transformer and Equipment	Workers	5–8	Crane or Boom Truck	1	Month 4-5
Delivery and Installation	2-Ton Truck	1	Tractor/Trailer	1	
	Pickup Truck	1	Portable Gas/Diesel Generator	1	
	Bucket Truck	2	_	-	
Control Enclosure Delivery and Install	Workers	6	Crane	1	Month 5
Remaining Equipment Delivery and Install	Workers	2–5	Boom Truck	1	Month 5-6
Cable Installation and Termination	Workers	5	Aerial Manlift	1	Month 5-6
Testing and Commissioning	Workers	2–5	Pickup Truck with Trailer	2	Month 6-7
Cleanup and Restoration	Workers	3	Front-End Loader	1	Month 7
	Blader	1	Water Truck	1	
70 kV Substation	*				
Site Work Area Preparation	Workers	6	Grader	1	Month 1-2
Mobilization	Backhoe/Dozer/Excavator	1	1-Ton Pickup Truck, 4 x 4	2	
Foundation Construction	Workers	6	Trencher	1	Month 2-3
	Hole Digger	1	1-Ton Pickup Truck, 4 x 4	1.75	
	Backhoe/Dozer/Excavator	1	_		
Ground Grid/Conduit Installation	Workers	4	1-Ton Pickup Truck, 4 x 4	1	Month 2-3
	Backhoe/Dozer/Excavator	1	Trencher	1	

Proposed Project Task	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Dates
Steel Bus Erection	Workers	8	Aerial Manlift	2	Month 3-4
	Boom Truck	2	1-Ton Pickup Truck, 4 x 4	2	
Equipment Delivery and	Workers	6	Aerial Manlift	2	Month 4
Installation	Boom Truck	1	1-Ton Pickup Truck, 4 x 4	2	
Control Enclosure Delivery and Install	Workers	5	1-Ton Pickup Truck, 4 x 4	2	Month 4
Cable Installation and Termination	Workers	5	1-Ton Pickup Truck, 4 x 4	2	Month 4-5
Install Yard Rock	Workers	6	Dump Truck	1	Month 5
	Bobcat	1	Backhoe/Dozer/Excavator	1	
Cleanup and Restoration	Workers	4	1-Ton Pickup Truck, 4 x 4	1	Month 5
Testing and Commissioning	Workers	4	1-Ton Pickup Truck, 4 x 4	1	Month 6
230 kV Transmission Interconnection	n				
Site Work Area Preparation	Workers	8	Grader	1	Month 1-2
Mobilization	1/2-Ton Pickup Truck, 4 x 4	1	1-Ton Crew Cab Flat Bed, 4 x 4	1	
	Backhoe/Dozer/Excavator	1	Water Truck	1	
Foundation Tower	Workers	10	Pickup Truck	2	Month 2-3
Installation/Removal of One	Crane	3	Dump Truck	1	
Tower	Bucket Truck	2	2-Ton Truck	2	
	Concrete Truck	2	Forklift	3	
	Drill	1	Line Truck	2	
	Backhoe	1	Water Truck	1	

Proposed Project Task	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Date
Conductor	Workers	15	Line Truck	2	Month 4
	Bucket Truck	2	Pickup Truck/Crew Truck	4	
	Crane	3	-	-	
Cleanup and Restoration	Workers	5	Pickup Truck	1	Month 5
	Grader	1	Water Truck	1	
	Backhoe	1	-	-	
70 kV Power Line					1
Reconductoring Segment					
Site Work Area Preparation Mobilization	Workers	6	Grader	1	Month 1
	1-Ton Crew Cab Flat Bed, 4 x 4	1	Water Truck	1	
	Pickup Truck	1	Backhoe	1	
Pole Installation/Transfer/	Workers	20	Water Truck	1	Month 2-7
Distribution/Removal	Crane/Basket	3	Helicopter	1	
	Heavy Crane	1	Bucket Truck	2	
	Drill	1	Line Truck	2	
	1-Ton Crew Cab Flat Bed, 4 x 4	3	2-Ton Truck	3	
	Pickup Truck	3	_		

Conductor Installation	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Dates	
Conductor installation	Workers	15	Wire Puller	1	Month 3-7	
	Line Truck	2	Tensioner	1		
	Pickup Truck	2	Wire Truck/Trailer	1		
	2-Ton Truck	2	Forklift	1		
	Crane/Basket	2	Medium Duty Helicopter	1		
	Bucket Truck	2	Water Truck	1		
Cleanup and Restoration	Workers	6	Backhoe	1	Month 8	
	Pickup Truck	1	Water Truck	1		
	Grader	1				
New 70 kV Power Line Segment						
Site Work Area Preparation	Workers	6	Grader	2	Month 8	
Mobilization	1-Ton Crew Cab Flat Bed, 4 x 4	1	Backhoe	1		
	Pickup Truck	1	Water Truck	2		
Pole Tower Installation	Workers	21	2-Ton Truck	3	Month 9-16	
	Concrete Truck	3	Line Truck	3		
	Backhoe	2	Utility Truck	1		
	Tractor Trailer	1	Water Truck	2		
	Pickup Truck	3	Crane	1		
	Bucket Truck	3	_	-		

Conductor Installation	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Dates
	Workers	18	Wire Truck/Trailer	1	Month 17-18
	Line Truck	3	Crane with Basket	3	
	Pickup Truck	3	Bucket Truck	2	
	2-Ton Truck	3	Light Duty Helicopter	1	
	Wire Puller	1	Fork Lift	1	
	Tensioner	1	Water Truck	1	
Cleanup and Restoration	Workers	6	Backhoe	1	Month 18
	Pickup Truck	1	Water Truck	1	
Reasonably Foreseeable Distributi	Grader	1	_	-	
					Total of 19
Reasonably Foreseeable Distributi	on Facilities ^{1, 2}				Weeks
Reasonably Foreseeable Distribution	on Facilities ^{1, 2} Workers	6	2-Ton Truck	1	
	1	6 3	2-Ton Truck Backhoe	1	Weeks
	Workers	-	-		Weeks
	Workers 1-Ton Crew Cab Flat Bed, 4 x 4	3	Backhoe	1	Weeks
Mobilization	Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Water Truck	3 1	Backhoe –	1 -	Weeks 2 weeks
Mobilization	Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Water Truck Workers	3 1 2–12	Backhoe - 2-Ton Truck	1 - 1–3	Weeks 2 weeks
Mobilization Foundation Construction	Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Water Truck Workers 1-Ton Crew Cab Flat Bed, 4 x 4	3 1 2–12 1–3	Backhoe - 2-Ton Truck Backhoe	1 - 1-3 1	Weeks 2 weeks 6 weeks
Mobilization Foundation Construction	Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Water Truck Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Workers	3 1 2–12 1–3 5–10	Backhoe - 2-Ton Truck Backhoe 2-Ton Truck	1 - 1-3 1 1	Weeks 2 weeks 6 weeks
Mobilization Foundation Construction Ground Grid/Conduit Installation	Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Water Truck Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Workers 1-Ton Crew Cab Flat Bed, 4 x 4	3 1 2-12 1-3 5-10 1-2	Backhoe - 2-Ton Truck Backhoe 2-Ton Truck Crane	1 - 1-3 1 1 1 1	Weeks 2 weeks 6 weeks 4 weeks
Mobilization Foundation Construction Ground Grid/Conduit Installation	Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Water Truck Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Workers 1-Ton Crew Cab Flat Bed, 4 x 4 Workers	3 1 2-12 1-3 5-10 1-2 5	Backhoe - 2-Ton Truck Backhoe 2-Ton Truck Crane Pickup Truck	1 - 1-3 1 1 1 1 1 1	Weeks 2 weeks 6 weeks 4 weeks

California Public Utilities Commission

2. Project Description

H-54 cont.

Proposed Project Task	Workers, Equipment	Quantity per Day	Equipment	Quantity per Day	Estimated Work Dates
Distribution Feeder, Conduit, Boxes, Underground Cable, Riser Poles, Line Work	Workers	8	Line Truck	2	6 weeks
	1-Ton Crew Cab Flat Bed, 4 x 4	1	Backhoe	1	
	2-Ton Truck	1	Crew Truck	2	
Cable Installation and Termination and Indoor Control Building Work	Workers	3–5	I-Ton Pickup Truck, 4 x 4	1	4 weeks
	1-Ton Crew Cab Flat Bed, 4 x 4	2	2-Ton Truck	1	
	Backhoe	1	-	=	
Testing	Workers	3	I-Ton Pickup Truck, 4 x 4	3–4	4 weeks
Cleanup and Restoration	Workers	3	1-Ton Crew Cab Flat Bed, 4 x 4	1	2 weeks
	1-Ton Pickup Truck, 4 x 4	3	Water Truck	1	
	Backhoe (or similar)	1		_	

Notes: kV = kilovolt

- 1. Assumes build-out of the reasonably foreseeable 70/21 kV facilities within the 70 kV substation and construction/reconductoring of the new Estrella distribution feeders.
- 2. Specific construction schedule information and personnel and equipment requirements associated with ultimate substation buildout are not known at this time.

Source: NEET West and PG&E 2017

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-85

California Public Utilities Commission 3. Response to Comments This page intentionally left blank.

2. Project Description

H-54 cont. Construction of the substation and power line would require approximately 10.3 million gallons of water total during the construction period (about 32 acre-feet), with 8.3 million gallons required for the substation and 2 million gallons required for the power line. About 25 percent of the total water used would be for construction activities (e.g., concrete mixing), with the remaining 75 percent used for dust control during the construction period. Daily water use during the construction period would vary based on the construction phase, but it is estimated that the average water use per day would be about 68,600 gallons. Portable restroom facilities would be provided at the site for worker use during the construction period.

2.5.5 Cleanup and Restoration

Surplus material, equipment, and construction debris would be removed at the completion of construction activities. All man-made construction debris would be removed and recycled or disposed of at permitted landfill sites. Cleared trees would be chipped and stored for later use during site restoration, left on the property owner's site, or disposed of off-site, depending on landowner and agency agreements.

All areas temporarily disturbed by the Project would be restored to the extent practicable, following construction. These disturbed areas include staging areas and access roads, work areas around each tower/pole, and the areas used for conductor stringing and staging. Post-construction restoration activities would include returning areas to their original contours and drainage patterns in accordance with stormwater pollution prevention plan best management practices and as prearranged through landowner agreements, where applicable.

All temporarily disturbed areas within and around Estrella Substation would be restored to the extent necessary for safe operation. All construction waste would be disposed of in accordance with applicable federal, state, and local laws regarding solid and hazardous waste disposal through transport to an authorized landfill.

2.6 Proposed Project Operations and Maintenance

The Applicants would operate all new and existing components of the Proposed Project according to their respective standard operating protocols and procedures. The Applicants anticipate using similar substation monitoring, control, and data acquisition architecture (e.g., SCADA) as used for their other power delivery assets, including the use of standard monitoring, control, protection equipment, circuit breakers, and other line relay protection equipment. The substation would be dual scanned from PG&E and HWT data centers, and redundant Inter-Control Center Communications Protocol servers would exchange SCADA data with CAISO with real-time situational awareness. The SCADA support personnel would perform daily checks of the applications and hardware to ensure they are in proper working order. The SCADA system would also be maintained to ensure compliance with NERC Critical Infrastructure Protection Standard requirements.

The proposed 230 kV substation would be remotely operated from a control center operated by a HWT affiliate, while the proposed 70 kV substation would be remotely operated by PG&E from its Grid Control Center. HWT and PG&E operations and maintenance personnel would generally perform monthly inspections of their respective substation facilities. More invasive checks, calibrations, and maintenance on the substation components would be performed periodically.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-86

2. Project Description

H-54

HWT has a CPUC-approved 2020 Wildfire Mitigation Plan (WMP) that provides a strategic framework for systematic reduction of HWT's potential wildfire risk and enhanced transmission system reliability. The 230 kV Estrella Substation would be incorporated into a future annual HWT submission of its WMP.

The proposed 70 kV power line components would operate unattended. An approximately 10-foot radius (approximately 314 square feet) may be maintained around new 70 kV power poles depending on location and equipment installed as required by applicable law, including CPUC G.O. 95. Project proponents may, therefore, keep these areas clear of natural vegetation. Vegetation growing too close to conductors within the easement would be trimmed or removed for safety. Herbicides may be used for some vegetation maintenance activities.

Inspections of the 70 kV power line segments would be performed annually by PG&E routine patrols, either from the ground or by helicopter. A detailed inspection of the power lines is typically performed by staff every 2 years (wood structures), with an air patrol inspection performed in between, as outlined in PG&E's 2016 Electric Transmission Preventative Maintenance Manual. For lines constructed on steel structures, detailed inspections would occur every 5 years. The inspection process involves routine patrols from existing local staff either on the ground or by helicopter tasked with patrolling the power lines. Normal inspection and patrols would typically be completed in a pickup truck and/or an off-road utility vehicle. While not expected, if walking is required, the inspector would complete portions of the inspection on foot. Climbing inspections would be performed on an as-needed basis, based on specific identified conditions and in compliance with CAISO guidelines and regulations.

With build-out of the distribution components, PG&E would continue to operate the 70 kV substation remotely from its Grid Control Center. The distribution feeders would continue to be operated and controlled from PG&E's Distribution Operations Office located in Concord, California. Existing operation and maintenance crews would monitor the distribution facilities as part of their current operation and maintenance activities. The distribution feeders would operate unattended.

2.7 Anticipated Permits and Approvals

The Proposed Project may be subject to a number of other regulatory permits and approvals, depending in part on the environmental analysis contained in this EIR, further surveys of environmental resources on or near the Proposed Project site, and the discretion of the regulatory agencies. Anticipated required permits and regulatory approvals for the Proposed Project are listed in Table 2-11 below.

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-87

2. Project Description



Table 2-11. Anticipated Permits and Approvals and Applicable Regulatory Requirements

Regulatory Agency	Jurisdiction/Purpose	Permit/Authorization Type		
Federal				
Federal Aviation Administration	Determination of No Hazard to Air Navigation	Aeronautical Study (7460-2 form)		
State				
California Public Utilities Commission	Construction, modification, or alteration of power line facilities	Permit to Construct (G.O. 131-D)		
California Department of Transportation	For use of California State highways for other than normal transportation purposes, including construction activities completed within the easement.	Standard Encroachment Permit		
California Department of Transportation	Some equipment, such as the 230/70kv transformer and the control house may require a permit for transporting oversize/overweight equipment.	Transportation Permit		
State Water Resources Control Board	Construction activities disturbing 1 acre or more of soil must submit a Notice of Intent to comply with the terms of the general permit.	National Pollution Discharge Elimination System Storm Water Permit		
Local or Regional				
San Luis Obispo Air Pollution Control District	For conducting activities which may result in air pollution.	Air Pollution Control District Permit		
City of Paso Robles	Construction in and adjacent to City property and right-of-way.	Encroachment Permit		
County of San Luis Obispo Construction in and adjacent t County property and right-of- way.		Encroachment Permit		

Source: NEET West and PG&E 2017

2.8 Applicant Proposed Measures

The Applicants propose to implement measures to avoid and/or reduce potential impacts of the Proposed Project. Applicant-proposed measures (APMs) that would be implemented for the

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-88

	California Public Utilities Commission		2. Project Description
H-54 cont.	Proposed Project are listed in Table	e 2-12.	
	Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report	2-89	December 2020 Project 17.010

California Public Utilities Commission 2. Project Description Table 2-12. Applicant-Proposed Measures Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components¹⁰ General GEN-1 Prepare and Implement a Worker Environmental Awareness Program. H-54 cont. The project proponents will prepare and implement a project-specific worker environmental awareness program (WEAP) for construction personnel. All on-site construction personnel will attend the training before they begin work on the project. WEAP training materials will include avoidance and minimization measures being implemented to protect biological resources, surface and groundwater resources, cultural resources, and paleontological resources; minimize air quality impacts; and manage hazardous materials. WEAP training will also discuss terms and conditions of any permits or agreements, information on federal and state environmental laws, and consequences and penalties for violation or noncompliance with these laws and regulations and project permits. Workers will be informed about the presence, identification, life history, and habitat requirements of the specialstatus species that have a potential to occur in the project area. More specifically, training will include: Recognizing/avoiding exclusion areas and sensitive habitat and specific avoidance or minimization measures for sensitive species and habitats; How to identify cultural resources; avoidance requirements and procedures to be followed if unanticipated cultural resources are discovered during construction; disciplinary actions that may occur when historic preservation laws and project proponent policies are violated; ¹⁰ If the distribution components are constructed at the same time as the rest of the Proposed Project. Estrella Substation and Paso Robles Area December 2020 2-Reinforcement Project Project 17.010

Draft Environmental Impact Report

California Public Utilities Commission

2. Project Description

H-54 cont.

		Applicability			
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰	
	How to identify paleontological resources, including types of fossils that could occur in the project area and types of lithologies in which the fossils could be preserved; avoidance requirements and procedures to be followed if a fossil is discovered during construction; penalties for disturbing paleontological resources; Hazardous substance spill prevention and containment measures; and Review of mitigation and avoidance measures. A brochure prepared by the project proponents conveying this information will be prepared for distribution to all construction staff and other individuals who enter the construction footprint. All WEAP trainees will receive a project sticker for their hard hat to show they have been trained, and will sign a training sign-in sheet verifying participation and that they understand the training and will comply with the information presented. Focused trainings may be directed at an individual's job-specific task, provided that the worker conducts activities within a limited scope (pilots, delivery drivers, site visitors, etc.).			Components	
Aesthetics	N 08 8 8		1	T	
AES-1	Substation Hardscaping. Decorative rock and/or other hardscape landscaping will be installed between Estrella Substation and Union Road.	√	N/A	N/A	
AES-2	Light and Glare Reduction. Construction lighting and permanent substation exterior lighting will be selectively placed and shielded to minimize nighttime glare.	✓	√	√	

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Components¹⁰ Substation **Power Line** Agriculture and Forest Resources AG-1 Coordinate with Landowners, Farmers, and Ranchers Regarding H-54 cont. Construction Activities. The project proponents will work with farmers, ranchers, and landowners to schedule project-related construction activities in a manner that avoids conflicts with harvest and planting periods, to the extent feasible, and in a manner that minimizes disruptions to agricultural operations. Access across active fields shall be negotiated with the landowner in advance of any construction activities. Coordination will include advance notice of construction activities and reporting of complaints, as follows: Prior to construction, the project proponents will give at least 30 days' advance notice of the start of construction-related activities. Notification shall be provided by mailing notices to all properties within 300 feet of the substation or power line route. The notice will describe where and when construction activity is planned and shall provide contact information for a point of contact for complaints related to construction activities. Prior to commencing ground-disturbing activities, the project proponents will submit a copy of the template used for the notification letter and a list of the landowners notified to the California Public Utilities Commission (CPUC). Estrella Substation and Paso Robles Area December 2020 2-Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Components¹⁰ Substation **Power Line** Air Quality AIR-1 H-54 Minimize Reactive Organic Gases (ROG), Oxides of Nitrogen (NOx), and cont. Particulate Matter (PM) Combustion. Maintain all construction equipment in proper tune according to manufacturer's specifications; ■ Fuel all off-road and portable diesel-powered equipment with California Air Resources Board (CARB)-certified motor vehicle diesel fuel (non-taxed version suitable for use off-road); Use on-road heavy-duty trucks that meet CARB's 2010 or cleaner certification standard for on-road heavy-duty diesel engines, and comply with the state On-Road Regulation; Construction or trucking companies with fleets that that do not have engines in their fleet that meet the engine standards identified in the above two measures (e.g., captive or NOx exempt area fleets) may be eligible by proving alternative compliance; All on and off-road diesel equipment shall not idle for more than 5 minutes. Signs shall be posted in the designated staging areas and substation site to remind drivers and operators of the 5-minute idling limit; Electrify equipment when feasible; Substitute gasoline-powered in place of diesel-powered equipment, where feasible; and Use alternatively fueled construction equipment on site where feasible, such as compressed natural gas (CNG), liquefied natural gas (LNG), propane, or biodiesel. Estrella Substation and Paso Robles Area December 2020 2-Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission

2. Project Description

H-54 cont.

		Applicability			
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰	
AIR-2	Air Quality Best Available Control Technology for Construction Equipment.	✓	✓	✓	
	Best available control technology measures for the project include:				
	 Reducing emissions by expanding use of Tier 3 off-road- and 2010 on- road-compliant engines; and 				
	 Installing California Verified Diesel Emission Control Strategies. 				
AIR-3	Minimize Fugitive Dust.	✓	✓	✓	
	Reduce the amount of the disturbed area where possible.				
	 Use water trucks or sprinkler systems in sufficient quantities to prevent airborne dust from leaving the site. 				
	 All dirt stock pile areas should be sprayed daily as needed. 				
	 All disturbed soil areas not subject to revegetation should be stabilized using approved chemical soil binders, jute netting, or other methods approved in advance by San Luis Obispo Air Pollution Control District. 				
	 Vehicle speed for all construction vehicles shall not exceed 15 mph on any unpaved surface. 				
	 All trucks hauling dirt, sand, soil, or other loose materials are to be covered or should maintain at least two feet of freeboard (minimum vertical distance between top of load and top of trailer) in accordance with California Vehicle Code Section 23114. 				
	 Sweep streets at the end of each day if visible soil material extending over 50 feet is carried onto adjacent paved roads. Water sweepers with reclaimed water should be used where possible. 				

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-

			Applicability	
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰
Biological I	Resources			
BIO-1	Conduct Pre-Construction Survey(s) for Special-Status Species and Sensitive Resource Areas. Biologists will conduct pre-construction survey(s) for special-status species and sensitive resource areas immediately prior to construction activities within suitable aquatic and upland habitat for special-status species. If a special-status species is encountered on the project site, the project proponents will be contacted immediately to determine the appropriate course of action. For federally or state listed species, the project proponents will contact the appropriate resource agency (U.S. Fish and Wildlife Service [USFWS] and/or California Department of Fish and Wildlife [CDFW]), as	√	*	V
	required.			
BIO-2	Avoid Impacts on Nesting Birds. If work is scheduled during the nesting season (February 1 through August 31), nest detection surveys will correspond with a standard buffer for individual species in accordance with the species-specific buffers set forth in the project proponent's Nesting Birds: Specific Buffers for PG&E Activities, and will occur within 15 days prior to the start of work activities at designated construction areas, staging areas, and landing zones to determine nesting status by a qualified biologist. Nest surveys will be accomplished by ground surveys and/or by helicopter and will support phased construction, with surveys scheduled to be repeated if construction lapses in a work area for 15 days between March and July. Access for ground surveys will be subject to property access permission. Helicopter flight restrictions for nest detection surveys may be in effect for densely populated residential areas, and will include observance of appropriate established buffers and avoidance of hovering in the vicinity of active nest sites.	·	,	ŕ

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components 10 If active nests containing eggs or young are found, the biologist will establish a species-specific nest buffer, as defined in the project proponent's Nesting Birds: Specific Buffers for PG&E Activities. Where feasible, standard buffers H-54 cont. will apply, although the biologist may increase or decrease the standard buffers in accordance with the factors set forth in Nesting Birds: Specific Buffers for PG&E Activities. Nesting pair acclimation to disturbance in areas with regularly occurring human activities will be considered when establishing nest buffers. The established buffers will remain in effect until the young have fledged or the nest is no longer active as confirmed by the biologist. Active nests will be periodically monitored until the biologist has determined that the young have fledged or once construction ends. Per the discretion of the biologist, vegetation removal by hand may be allowed within nest buffers or in areas of potential nesting activity. Inactive nests may be removed in accordance with PG&E's approved avian permits. The biologist will have authority to order cessation of nearby project activities if nesting pairs exhibit signs of disturbance. All references in this applicant-proposed measure (APM) to qualified wildlife biologists refer to qualified biologists with a bachelor's degree or above in a biological science field and demonstrated field expertise in ornithology, in particular, nesting behavior. BIO-3 Biological Monitoring. Biologists will monitor initial ground-disturbing activities in and adjacent to sensitive habitat areas to ensure compliance with best management practices and APMs, unless the area has been protected by barrier fencing to protect sensitive biological resources and has been cleared by the biologists. The monitor will have authority to stop or redirect work if construction activities are likely to affect sensitive biological resources. Estrella Substation and Paso Robles Area 2-December 2020 Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components 10 If a listed wildlife species is encountered during construction, project activities will cease in the area where the animal is found until the qualified biologist determines that the animal has moved out of harm's way or, with H-54 prior authorization from USFWS and/or CDFW if required, relocates the cont. animal out of harm's way and/or takes other appropriate steps to protect the animal. Work may resume once the qualified biologist has determined that construction activities will not harm any listed wildlife species. The project proponents will be responsible for any necessary reporting to USFWS and/or CDFW. BIO-4 Special-Status Species Protection. All trenches/excavations in excess of 2 feet deep will have a sloped escape ramp or be covered at the end of the day. All trenches and excavations will be inspected for wildlife at the beginning of the workday and prior to backfilling. In addition, open-ended project-related pipes 4 inches or greater in diameter will be capped if left overnight or inspected for wildlife prior to being moved. If a special-status species is discovered in a trench, excavation, or pipe, the animal will be left undisturbed, and the pipe will not be moved until the special-status species has left the area on its own accord. In the event that any special-status species is trapped and unable to leave on its own accord, a permitted biologist, defined as a qualified biologist that holds the appropriate federal and/or state permits, will recover and relocate the special-status species. In addition, all food scraps, wrappers, food containers, cans, bottles, and other trash from the project area will be deposited in closed trash containers or kept in closed vehicles. Trash containers will be removed from the project area on a regular basis. Estrella Substation and Paso Robles Area December 2020 2-Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Components¹⁰ Substation **Power Line** BIO-5 Dead or Injured Special-Status Wildlife. If any dead or injured special-status wildlife or birds protected by the Migratory Bird Treaty Act are discovered at the project site during construction, work will stop in the immediate vicinity. The project proponents H-54 will notify the on-call biologist and the appropriate resource agency (USFWS cont. and/or CDFW) before construction is allowed to resume. **Cultural Resources** CUL-1 Retain a Qualified Cultural Principal Investigator. A cultural resources principal investigator, defined as an archaeologist who meets the Secretary of the Interior's Standards for professional archaeology, will be retained to ensure that all APMs related to archaeological and historical resources are properly implemented. The principal investigator may either be on staff with project proponents or an outside consultant, as appropriate for the project's needs, and will serve in a strictly supervisory capacity, overseeing crews charged with the application of the APMs in the field. CUL-2 N/A N/A Avoidance. The project is designed to avoid impacts to potentially CRHR-eligible resources identified within the study area. Potentially eligible (i.e., not evaluated) resources in the study area include archaeological sites 36052-S-001, 36052-S-002, and 36052-S-003. In addition, the Johnson House was evaluated for the project and is considered CRHR-eligible (pending CPUC concurrence). To avoid indirect and direct impacts to 36052-S-001, 36052-S-002, or 36052-S-003, a 50-foot buffer will be established around the boundary of each respective resource and designated as environmentally sensitive areas. If work within the 50-foot buffer cannot be avoided, then Estrella Substation and Paso Robles Area December 2020 2-Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components 10 monitoring will be required. Methods of environmentally sensitive area delineation may include, as applicable, flagging, rope, tape, or fencing. The environmentally sensitive areas should be clearly marked on all pertinent H-54 construction plans. Construction activities will avoid impacts to the Johnson cont. House entirely. CUL-3 Inadvertent Discoveries. In the event that unanticipated cultural materials are encountered during any phase of construction, all construction work within 50 feet of the discovery will cease and the principal investigator will be consulted to assess the find. Construction activities may continue in other areas. Avoidance of resources is the preferred option. However, if avoidance of a resource is not feasible, project proponents will assess the find for significance, as defined by PRC Section 21083.2, through implementation of Phase II investigations. If resources are found to be significant, a detailed archaeological treatment plan, including Phase III data recovery, will be developed and implemented by a qualified archaeologist. CUL-4 Discovery of Human Remains. If human remains are discovered, all work within 50 feet of the discovery will cease and the environmental inspector or construction supervisor will notify the County coroner immediately. State of California Health and Safety Code Section 7050.5 stipulates that no further disturbance will occur until the County Coroner has made a determination of origin and disposition pursuant to PRC Section 5097.98. The lead cultural resource managers on staff with the project proponents (depending on the location of the remains) and the CPUC will also be notified of the find immediately. If the human remains are determined to be prehistoric, the County Coroner will notify the Native American Heritage Commission (NAHC), which would determine and notify a Estrella Substation and Paso Robles Area December 2020 2-Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description

H-54 cont.

			Applicability		
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰	
	most likely descendent. The most likely descendent will complete inspection of the site within 48 hours of notification and may recommend scientific removal and nondestructive analysis of human remains and items associated with Native American burials.				
CUL-5	Tribal Construction Monitoring.	N/A	/	N/A	
	If it becomes necessary to work within 50 feet of Dry Creek, Huer Huero Creek, and the Salinas River, or known prehistoric archaeological sites, a tribal monitor will be selected by the CPUC and retained to conduct full-time monitoring of initial ground-disturbing activities (i.e., initial excavation and grading) in areas with high potential to discover prehistoric archaeological resources.				
CUL-6	Archaeological Construction Monitoring. If it becomes necessary to work within 50 feet of Dry Creek, Huer Huero Creek, and the Salinas River, or known prehistoric or historic sites, an archaeological monitor, approved by the principal investigator, will be retained to conduct monitoring of initial ground-disturbing activities (i.e., initial excavation and grading) in areas with high potential to discover prehistoric or historic archaeological resources.	N/A	*	N/A	
Geology an	nd Soils (including Paleontological Resources)				
GEO-1	Soft or Loose Soils. Soft or loose soils, such as sands and loamy sands, are likely to be encountered during construction. Where soft or loose soils are encountered during design studies or construction, appropriate measures will be implemented to avoid, accommodate, replace, or improve soft or loose soils. Such measures may include the following:	V	·	√	

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-

California Public Utilities Commission 2. Project Description

H-54 cont.

APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰
	 Locating construction facilities and operation away from areas of soft and loose soil. Over-excavating soft or loose soils and replacing them with non-expansive engineered fill. Increasing the density and strength of soft or loose soils through mechanical vibration and/or compaction. Treating soft or loose soils in place with binding or cementing agents. Construction activities in areas where soft or loose soils are encountered may be scheduled for the dry season, as necessary, to allow safe and reliable equipment access. 			
PALEO-1	Retain a Qualified Paleontological Principal Investigator. A paleontological resources principal investigator who meets the standards set forth by the Society of Vertebrate Paleontology will be retained to ensure that all APMs related to paleontological resources are properly implemented.	✓	√	~
PALEO-2	Inadvertent Discoveries. If paleontological resources are discovered during construction activities, the following procedures will be followed: Stop work immediately within 50 feet. Contact the designated lead on staff with the project proponents (depending on the location of the resource) immediately. The designated lead will notify the CPUC. Protect the site from further impacts, including looting, erosion, or other human or natural damage. The principal investigator will evaluate the discovery and make a recommendation to the CPUC as to whether or not it is a unique paleontological resource. The CPUC will have 24 hours to respond to	√	*	√

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-101

California Public Utilities Commission 2. Project Description

H-54 cont.

			Applicability	
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰
APM No.	Title/Description this recommendation, and the lack of response within 48 hours will indicate concurrence with the recommendation. If the resource is not a unique paleontological resource, then it will be documented appropriately, and no further measures will be required. If the resource is a unique paleontological resource, the principal investigator, in consultation with the project proponent, will recommend resource-specific measures to protect and document the paleontological resource, such as photo documentation and avoidance or collection. The CPUC will have 24 hours to respond to these measures, with no response within 48 hours indicating concurrence. Unique resources inadvertently discovered during augering will be documented as indicated above, but, due to safety concerns, any remaining resource below ground will not be salvaged. If the resource can be avoided, then CPUC concurrence will not be necessary. If collection is necessary, the fossil material will be properly prepared in accordance with the project proponents, Society of Vertebrate Paleontology guidelines, and CPUC requirements, and/or curation at a recognized museum repository. Appropriate documentation will be		Power Line	
	included with all curated materials. Any material discovered on private land is the property of the landowner and permission must be granted by the landowner for the material to be removed and curated. Once the resource is determined to be not unique, or appropriate treatment is completed as described above, work may resume in the vicinity.			

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-102

California Public Utilities Commission 2. Project Description

H-54 cont.

		Applicability		
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰
PALEO-3	Paleontological Construction Monitoring.	✓	✓	✓
	Paleontological monitors, approved by the paleontological resources principal investigator, will be retained to conduct monitoring of the initial ground-disturbing activities as described below. Monitoring requirements vary with the sensitivity of the mapped sediments and the type of construction activity, as follows: 1. Estrella Substation: High Surface Sensitivity – project areas mapped as older alluvium (Qoa) or Paso Robles formation (Qtp): In locations where the ground has been previously disturbed by agricultural or other development, monitoring is required only when excavations or grading exceed the depth of previous disturbance. For augering within the substation site, the proponents will follow the protocol identified below under Power Line. In locations where no previous disturbance exists, full-time monitoring is required when excavations, grading, or trenching exceeds 3 feet in depth. During monitoring, a qualified paleontological monitor, as determined by the principal investigator, will observe construction activity as well as check any spoils piles to watch for the appearance of fossil resources. Low Surface Sensitivity – project areas mapped as Holocene alluvium (Qa or Qg) – no fossils at the surface: No monitoring is required for surface work.			

Estrella Substation and Paso Robles Area Reinforcement Project Draft Environmental Impact Report 2-103

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components 10 Should ground disturbance exceed the depth of the Holocene sediments (estimated to be 5 feet), monitoring is required as described above for high sensitivity. H-54 2. Power Line: cont. High Surface Sensitivity - project areas mapped as older alluvium (Qoa) or Paso Robles formation (Qtp): Full-time monitoring will not be required along the power line Augering that uses a drill bit 3 feet, or less, in diameter will not be monitored. Small-diameter drill bits generally result in pulverized rock by the time they reach the surface, so any fossils contained within will not be identifiable. Larger-diameter drill bits (i.e., greater than 3 feet) often bring up intact chunks of rocks that may contain identifiable and scientifically important fossils (particularly microfossils). All large angled tubular steel pole locations will be monitored. During work, a portion of the excavated material will be examined visually and through screen-sifting, if necessary. If screening is necessary, then a sample of spoils may be collected and processed either on site or off site as work on the pole placement proceeds. Should unique fossil material be discovered, it may be recorded and collected if the resource is determined by the principal investigator to be worth salvaging. Otherwise it will be recorded and included in the final monitoring report. Should it be determined that the type of auger or drill being used renders monitoring not useful (i.e., materials come out of the hole in a Estrella Substation and Paso Robles Area December 2020 2-104 Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components 10 pulverized powder or a silty mud), monitoring will be discontinued. Because it is extremely unsafe and impractical to excavate fossils H-54 cont. from within an auger bore or drill hole, and to do so would unnecessarily disturb fossils further, no effort will be made to collect buried fossils indicated in spoils materials. However, the location and nature of the materials identified will be recorded, and this will be documented in the final monitoring report and reported to repositories as appropriate. These measures are based on the currently available data. As construction proceeds and additional data become available, the principal investigator could revise these measures with CPUC concurrence. Should monitors identify fossil remains during the course of construction, APM PALEO-2 will be implemented. All monitoring activities will be documented on daily logs. Monitoring logs and reports will include the activities observed, geology encountered, description of any resources encountered, and measures taken to protect or recover discoveries. Photographs and other supplemental information will be included as necessary. A final monitoring report will be developed to document locations, methods, and results of monitoring. PALEO-4 Fossil Recovery. In the event that unique paleontological resources are encountered, protection and recovery of those resources may be required. The principal investigator will oversee the recovery effort in consultation with the project proponents (depending on the location of the resource), the CPUC, and property owners as appropriate. The principal investigator may designate a paleontologist to implement the recovery, prepare specimens for Estrella Substation and Paso Robles Area 2-105 December 2020 Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

California Public Utilities Commission 2. Project Description Applicability Estrella Distribution APM No. Title/Description Substation **Power Line** Components 10 identification and preservation, and complete all field documentation in accordance with the project proponents, Society of Vertebrate Paleontology guidelines, and CPUC requirements, and/or curation at a recognized museum H-54 cont. repository. If a fossil is not accepted by a museum for curation, then project proponents will have fulfilled their obligation for fossil recovery. Greenhouse Gas Emissions GHG-1 N/A N/A Minimize Operational Sulfur Hexafluoride (SF₆) Emissions. During operation and maintenance of Estrella Substation, the project proponents will do the following: Incorporate Estrella Substation into each of the project proponents' system-wide SF₆ emission reduction programs. CARB requires that company-wide SF6 emission rate not exceed 1 percent by 2020. Upon construction completion, the project proponents will have implemented a programmatic plan to inventory, track, and recycle SF₆ inputs, and inventory and monitor system-wide SF₆ leakage rates to facilitate timely replacement of leaking breakers. X-ray technology is used to inspect internal circuit breaker components to eliminate dismantling of breakers, reducing SF6 handling and accidental releases. As active members of the U.S. Environmental Protection Agency's SF₆ Emission Reduction Partnership for Electrical Power Systems, the project proponents have focused on reducing SF₆ emissions from their transmission and distribution operations. Require that the breakers at Estrella Substation have a manufacturer's guaranteed maximum leakage rate of 0.5 percent per year or less for Estrella Substation and Paso Robles Area December 2020 2-106 Reinforcement Project Project 17.010 **Draft Environmental Impact Report**

		Applicability		
APM No.	Title/Description	Estrella Substation	Power Line	Distribution Components ¹⁰
	Maintain substation breakers in accordance with the project			
	proponents' maintenance standards.			
	■ Comply with CARB's Early Action Items as these policies become			
	effective.			
Hazards a	nd Hazardous Materials			
HAZ-1	Hazardous Substance Control and Emergency Response.	✓	✓	✓
	The project proponents will implement hazardous substance control and			
	emergency response procedures as needed. The procedures identify			
	methods and techniques to minimize the exposure of the public and site			
	workers to potentially hazardous materials during all phases of project			
	construction through operation. The procedures address worker training			
	appropriate to the site worker's role in hazardous substance control and			
	emergency response. The procedures also require implementing appropriate			
	control methods and approved containment and spill-control practices for			
	construction and materials stored on site. If it is necessary to store chemicals			
	on site, they will be managed in accordance with all applicable regulations.			
	Material safety data sheets will be maintained and kept available on site, as			
	applicable.			
	In the event that soils suspected of being contaminated (on the basis of			
	visual, olfactory, or other evidence) are removed during site grading activities			
	or excavation activities, the excavated soil will be tested and, if contaminated			
	above hazardous waste levels, will be contained and disposed of at a licensed			
	waste facility. The presence of known or suspected contaminated soil will			
	require testing and investigation procedures to be supervised by a qualified			
	person, as appropriate, to meet state and federal regulations.			
	All hazardous materials and hazardous wastes will be handled, stored, and			
	disposed of in accordance with all applicable regulations, by personnel			