

## Lincoln Allen

---

**From:** Lincoln Allen  
**Sent:** Wednesday, March 20, 2019 10:56 AM  
**To:** Lincoln Allen  
**Subject:** Addendum #3 and MPR Request #3 / Suncrest Construction Fire Prevention Plan (CFPP)

### Addendum #3 / Suncrest Construction Fire Prevention Plan (CFPP)

The Suncrest Construction Fire Protection Plan (CFPP) calls for vehicles and equipment to be parked with a 30 foot clearance from vegetation. This distance between parked equipment and vegetation has been determined to unnecessary and impracticable for crews and equipment on the ground. Instead the contractor is proposing a 10 foot buffer between parked equipment and vegetation. Per James Pine, Assistant Fire Marshall for San Diego County Fire, on 3/18/19, he accepts a revision to the CFPP that vehicles are to be parked in areas devoid of any vegetation and with a minimum distance of 10 feet from any vegetation.

---

**From:** K Keenen  
**Sent:** Tuesday, March 19, 2019 12:02 PM  
**To:** David Farkas; Steve Combs; Adrienne Charbonneau; Lincoln Allen; D Hochart  
**Subject:** EXTERNAL:Fwd: Fire plan variance

Sent from my iPhone

Begin forwarded message:

**From:** Pine, James  
**Date:** March 19, 2019 at 9:23:02 AM PDT  
**To:** K Keenan  
**Subject:** RE: Fire plan variance

Good Morning Keenen,

We can accept a revision to the CFPP that vehicles are to be parked in areas devoid of any vegetation and be a minimum of 10 feet from any vegetation.

Best Regards,

JAMES PINE | Asst. Fire Marshal  
San Diego County Fire Authority  
5510 Overland Ave., Suite 250  
San Diego, CA 92123  
T: 858.495.5434  
Office Hrs.: M-Th, 7:00-5:30

Improving Fire and Emergency Medical

Services in Unincorporated San Diego County

[www.sdcountyfire.org](http://www.sdcountyfire.org)

Please take a moment to complete this brief customer service survey. Your input and comments are important to us as we strive to serve you better: <https://www.surveymonkey.com/r/psg-sdcfa-feedback>

CONFIDENTIALITY NOTICE: This email message, including any attachments, is for the sole use of the intended recipient(s) and may contain information protected from disclosure by applicable laws and regulations. If you are not an intended recipient, you may not review, use, copy, disclose or distribute this message or any of the information contained in this message to anyone. If you are not the intended recipient, please contact the sender by reply email and destroy all copies of this message and any attachments. Unintended transmission shall not constitute waiver of any applicable legal protection afforded to this email and any attached documents.

-----Original Message-----

From: K Keenan

Sent: Tuesday, March 19, 2019 8:35 AM

To: Pine, James

Subject: Re: Fire plan variance

Good morning, thanks for the reply. This is with the Suncrest dynamic reactive power support project that is building a static var compensator off of Bell Bluff TT and connecting in with the existing Suncrest substation, near Descanso.

Sent from my iPhone

On Mar 19, 2019, at 7:52 AM, Pine, James wrote:

Good Morning Keenen,

Which project is this regarding?

Best Regards,

JAMES PINE | Asst. Fire Marshal

San Diego County Fire Authority

5510 Overland Ave., Suite 250

San Diego, CA 92123

T: 858.495.5434

Office Hrs.: M-Th, 7:00-5:30

Improving Fire and Emergency Medical

Services in Unincorporated San Diego County [www.sdcountyfire.org](http://www.sdcountyfire.org)

Please take a moment to complete this brief customer service survey.  
Your input and comments are important to us as we strive to serve you  
better: <https://www.surveymonkey.com/r/psg-sdcfa-feedback>

CONFIDENTIALITY NOTICE: This email message, including any attachments, is for the sole use of the intended recipient(s) and may contain information protected from disclosure by applicable laws and regulations. If you are not an intended recipient, you may not review, use, copy, disclose or distribute this message or any of the information contained in this message to anyone. If you are not the intended recipient, please contact the sender by reply email and destroy all copies of this message and any attachments. Unintended transmission shall not constitute waiver of any applicable legal protection afforded to this email and any attached documents.

-----Original Message-----

From: K Keenan  
Sent: Monday, March 18, 2019 6:32 PM  
To: Pine, James  
Subject: Fire plan variance

Good afternoon Assistant Fire Marshal Pine. I was asked to reach out for approval to amend or make a variance to the fire plan. According to the fire plan, vehicles and equipment must be parked with 30 feet clearance from vegetation. I feel that this is not necessary and unrealistic for crews to comply. I am requesting your approval to change the clearance requirement for parked vehicles and equipment down to 10 feet. This distance is a more common and realistic mitigation measure that should still be more than sufficient. Thank you for your consideration and let me know your decision at your convenience.

Sent from my iPhone