

From Structure #	To Structure #	Ground Clearance (ft) to			Wire-to-Wire Clearance (ft) to ADSS from	
		230kV ACSS (MOT = 280F)	230kV ACSR (MOT = 194F)	FO ADSS (MOT = 130F)	230kV ACSS	230kV ACSR
PENASQUITOS	2	56.1	56.4	N/A	N/A	N/A
2	3	93.6	91.9	79.0	13.6	12.2
3	4	43.1	37.8	22.5	11.9	12.5
4	5	47.1	45.9	32.5	12.0	12.6
5	6	39.9	40.4	25.8	11.4	11.6
6	7	58.8	67.8	35.4	13.9	14.8
7	8	54.7	45.6	33.2	11.8	12.9
8	9	41.0	42.3	29.1	11.6	11.9
9	10	42.7	43.3	29.9	12.0	11.9
10	11	32.7	34.0	19.1	11.6	11.3
11	12	55.8	45.6	30.8	11.1	11.2
12	CC MM CP	39.9	35.5	23.6	13.4	11.4

Wire Concerned Voltage (kV)	Required Ground Clearance (ft) Per GO 95	Required Wire-to-Wire Clearance (ft) to ADSS Per GO 95
230	30	9.92
0	18	N/A