

# SUBSTATION SECURITY VALMONT COMPOSITES SAFEFENCE



#### SafeFence FRP (Fiber-reinforced polymer)

- Pultruded fiberglass tongue and groove security barrier
- Manufactured in 6", 12" and 24" planks.
- Each plank is pultruded and then cut to the size per specification.
- The final step is a urethane coating to add additional UV protection and longevity.
- Ballistic material can be installed to provide additional security
- Fencing columns and gates are also FRP to provide a complete solution





#### **Valmont FRP Fencing History**

1988 1<sup>st</sup> Installation Highway

1998 1<sup>st</sup> Installation Railroad

2009 1<sup>st</sup> Installation with Fiberglass Uprights

2016 Introduced 12" Panel Highway & Retaining

2017 Introduced C Shape Safe Fence

2019 1st Installation of Ballistic Panel Substation

2022 2' Panel & 12" Wide Flange Upright

2024 New Ballistic Vented Wall





#### Why FRP Fencing

- Modular, lightweight design No heavy equipment required for installation or repairs
- More cost effective, stronger and resilient than other materials, both to install and maintain
- Both a <u>nonconductive</u> and <u>noncorrosive</u> solution
- High strength to weight ratio
- Adaptive to extreme climates and environmental conditions
- Highly durable...50-year service life

## Valmont SafeFence™ **Industry Testing**

Туре	Test Criteria	Result
UV	ASTM G154 Weathering Test	• Pass
Acoustical	• ASTM E-90 & ASTM C423	• Pass
Flashover	• ASTM 5711-2013. ASTM D149-2013, IEEE 978-1984	• Pass
Wall Design	AASHTO LRFD Bridge Design & ASCE 7-10/16	• Pass
Smoke & Flame	• ASTM E84-00A (ANSI 2.5, NFPA 255, UBC 8-1 (40-1) UB 723)	• Pass
Testing Forced Entry and Ballistic	• ASTM F2781-15 & UL 752	• Pass














RAL 6003	Olive Green
RAL 7035	Light Grey
RAL 1015	Light Ivory
RAL 6002	Leaf Green
RAL 9003	Signal White
C0163	SKP Brown
Fed Std. 20219	Cocoa Brown














TYP, FENCE SECTION W/ 20'-0" MOTORIZED GATE

								DSGN	LS POWER GRID CALIFORNIA, LLC	JOB NUMBER	REV
								DRN		412040	
								CKD	COLLINSVILLE SUBSTATION		$  \angle B \setminus  $
								SCALE:	500KV CIS	DRAWING NUM	/BER
	FOR REFERENCE ONLY								500KV GIS SUBSTATION FENCE DETAIL	DRAWING NUMI CL-C-FNC-	-002
REV	REVISIONS	DATE	DRN	DSGN	CKD APF	PD	REFERENCE DRAWINGS	FOR 22x34 DWG ONLY	FENCE DETAIL	SHEET 1 OF	F 2